

LUMEL

RAIL MOUNTED POWER NETWORK METER
NR30



USER'S MANUAL

CE

Contents

1	APPLICATION.....	3
2	METER SET.....	3
3	BASIC REQUIREMENTS, OPERATIONAL SAFETY	3
4	INSTALLATION	4
5	DESCRIPTION.....	4
5.1	Current inputs.....	4
5.2	Voltage inputs.....	4
5.3	Connection of the meter	5
5.4	External connections diagram	6
6	COOPERATION WITH S4AO	9
7	NR30 PROGRAMMING.....	10
7.1	Frontal panel.....	10
7.2	6.2. Messages after Switching the Supply on.....	11
7.3	Starting operation	11
7.4	Language selection.....	12
8	OPERATING MODES	12
8.1	Measurement mode	15
8.1.1	Measurement of voltage and current harmonics	16
8.2	Parameters mode	16
8.3	Alarm mode.....	17
8.4	Display mode.....	20
8.5	Archiving mode.....	23
8.6	Ethernet mode	27
8.7	Modbus mode.....	28
8.8	Settings mode	28
8.9	Information mode	28
9	EXTENDED FUNCTIONALITY	30
10	MEASURED VALUES ARCHIVING	30
10.1	INTERNAL MEMORY.....	30
10.2	COPYING THE ARCHIVE	30
10.3	STRUCTURE OF ARCHIVE FILES.....	31
10.4	DOWNLOADING THE ARCHIVE	31
11	SERIAL INTERFACES.....	31
11.1	RS485 INTERFACE – the list of parameters.....	31
11.2	Examples of registers reading and saving.....	32
11.3	Ethernet 10/100-BASE-T	34
11.3.1	Connection of 10/100 BASE-T interface.....	35
11.3.2	Web server.....	36

11.3.3	FTP server	38
11.3.4	Modbus TCP/IP	39
12	MAP OF REGISTERS OF NR30 METER	40
13	FIRMWARE UPGRADE.....	60
13.1	Update of the meter website	60
13.2	Firmware upgrade - the main program of the meter.....	61
14	ERROR CODES	62
15	TECHNICAL DATA.....	63
16	ORDERING CODES.....	66

1 APPLICATION

NR30 meter is a digital programmable instrument designed to measure network parameters of single-phase 2-wire and three-phase 3 and 4-wire balanced and unbalanced systems. The measured values are displayed on a 20 x 4 LCD character display. The meter enables controlling and optimizing the operation of power electronics devices, systems and industrial installations.

It provides measurement of: RMS voltage and current, active, reactive and apparent power, active, reactive and apparent energy, power factors, frequency, harmonic currents and voltages / up to 51st /, THD of current and voltage, average active and apparent power, P Demand, S Demand, averaged current I Demand /15, 30 or 60 minutes/. Voltages and currents are multiplied by given voltage and current ratios of measuring transformers / for indirect connections /. Indications of power and energy take into consideration values of programmed ratios. The values of the measured quantities can be transmitted to the host system through RS485 interface or Ethernet interface, relay outputs signal overruns of the selected parameters.

The meter has a galvanic separation between the individual blocks of:

- power supply,
- voltage inputs,
- current inputs (for versions In 1 A/ 5 A),
- RS485 Interface,
- Ethernet Interface:
- alarm outputs,

2 METER SET

Complete set of the Analyzer includes:

1. NR30 meter	1 pc.
2. User's manual – Quick Start	1 pc.

3 BASIC REQUIREMENTS, OPERATIONAL SAFETY

In terms of operational safety, the meter meets the requirements of DIN EN 61010-1.

Safety instructions:

- The meter installation and connection should be made by qualified personnel. All available protection requirements must be taken into consideration.
- Before turning the meter on verify the connections.
- Prior to removing the meter housing, always turn the supply off and disconnect the measurement circuits.
- Removal of the meter housing during the warranty period voids the warranty.
- The meter meets the requirements for electromagnetic compatibility in industrial environment.
- A switch or a circuit-breaker should be installed in the building or facility. It should be located near the device, easily accessible to the operator, and suitably marked.

4 INSTALLATION

The meter is adapted for installation in a modular installation switchgears on a 35 mm support rail. The housing of the meter is made of plastic.

Housing dimensions are 105 x 110 x 60 mm. Outside the meter there are screw terminal strips that allow connection of external wires with a cross-section up to 5.3 mm² / indirect measurements/ and up to 16 mm² /direct measurements.




Fig.1. Overall dimensions of NR30 meter

5 DESCRIPTION

5.1 Current inputs

All current inputs are galvanically isolated (internal current transformers). The meter is adapted for direct connections / up to 63 A / or for use with external current transformers / 1 A or 5 A /. Displayed values of currents and derivative quantities are automatically converted according to the introduced external current transformer ratio.


5.2 Voltage inputs

Quantities at voltage inputs are automatically calculated by the amount of introduced ratio of the external voltage transformer. Voltage inputs are defined in the order as 3x57.7/100 V up to 3x100/170 V or 3x230/400 V up to 3x400/690 V.

5.3 Connection of the meter

Description of the meter external terminals is shown in Fig 2.

a)



b)




Fig.2. Connection of the meter: a) in the version for indirect connections (1 / 5 A)

b) in the version for direct connections (63 A)

5.4 External connections diagram




Fig.3. Direct, semi-direct and indirect measurement in 1-phase network






Fig.4. Direct measurement in 4-wire network version 63 A

Direct measurement
in 4-wire network



Semi-indirect measurement in 4-wire network



Indirect measurement
in 4-wire network






Fig.5. Input signal connection in 3-phase 4 - wire network

Direct measurement in 3 - wire network



Semi-direct measurement
using 2 current transformers in
3 - wire network.



Indirect measurement using 2 current
transformers and 2 or 3 voltage
transformers in 3 - wire network.




Fig.6. Input signal connection in 3-phase 3 - wire network

6 COOPERATION WITH S4AO

For NR30 versions with the S4AO block of 4 analog outputs, side connector for connecting blocks is included. The connector can also be ordered separately: order code 24-171-01-00016




Fig.7. Connecting blocks using the side connector




Fig.8. Connection of NR30 with S4AO using RS485 interface

The S4AO module communicates with the NR30 meter via the RS485 Modbus Master interface, therefore cooperation with S4AO excludes the use of the NR30 meter RS485 interface for communication with another Master.

7 NR30 PROGRAMMING

7.1 Frontal panel



Fig.9. Frontal panel

NR30 meter has 3 buttons and a 20 x 4 LCD character display.
Description of the frontal panel:

-  value increase key
and moving up
 -  button to decrease the value
and moving down
 -  accept key
 -  USB socket

V,A,W,var, VA, units of displayed quantities k, M, G kilo = 10^3 , Mega = 10^6 , Giga = 10^9
 Wh, varh,
 Hz,

U1,I1, P1, ... Indications of displayed parameters L, C markers of the type of load
 ..EnQ

The values of measured parameters are presented on active pages selected by subsequent pressing of the buttons  (next page) or  (previous page). Page size is determined by any 3 quantities selected from Table 1 and displayed on the screen. Defining pages is described under **Displaying** mode.

The information bar at the top of the screen shows the status of the alarm outputs, alarm conditions, file archive memory status, archiving status. There is also an Ethernet connection symbol on the information bar, indicators of receiving and transmitting data to the RS485 line. In the case of reverse phase sequence, the symbol "!" flashes. When displaying the minimum, maximum or harmonic values, the corresponding information appears.





Fig.10. Information bar

Symbol	Information
MIN MAX	Pressing the button displays the minimum, maximum or current value (no symbol) of the displayed quantity.
!	If voltage signals are connected in reverse sequence, the symbol indicating the phase sequence error flashes.
A1, A2	Status of alarm outputs. In the event of an alarm (s), the corresponding symbols are displayed.
1 2 3	Signaling of meeting the alarm conditions
File archive memory status	
M ^{OO}	Percentage of usage of the file archive memory, e.g. M ²⁸
M?	Lack of archive memory or incorrect archive memory file system
F ⁹⁷	It blinks every 1 second. Less than 7% of free space left in the file archive memory. Time to complete filling the archive of files about 14 days at 1 sec. interval. Immediately delete unnecessary files via FTP. When the file archive is full to 95%, the overwrite mode is started, in which during further archiving and creating new archive files, the oldest archived files are deleted.
D ⁵⁴	It blinks every 1 second. Copying from internal memory to the file archive memory. The field displays the percentage of copying progress.
E	Ethernet connection symbol
R T	Indicator of receiving and transmitting data to the RS485 line

7.2 6.2. Messages after Switching the Supply on

7.3 Starting operation

When power is turned on, the meter displays the logo, NR30 meter name, version, current firmware version and MAC for versions with Ethernet, and then switches to measurement mode displaying the page which was set as the last one. Displayed information:

**Fig.11. Welcome screen**

NR30 – meter type, brand

Bv: 01. 06 – bootloader version no., Fv: 0. 80 – firmware version no.

U: 3x230. 0. . . 3x400. 0 V – voltage versions

63 – current versions

7.4 Language selection

The preset language is English. To select a different language, press and hold the button for about 10 seconds. The language selection menu will then appear. The language selection is made with the or buttons and then confirmed again by pressing the accept button.

8 OPERATING MODES

The NR30 meter has 9 operating modes:

Measurement – normal operation mode. The values of quantities are displayed according to pre-programmed pages or pages configured by the user in the Displaying mode.

Parameters – configuration of parameters of the meter,

Alarms – alarm configuration Alarm 1, Alarm 2,

Displaying – configuration of displayed pages,

Archiving – configuration of archived quantities,

Ethernet – configuration of Ethernet interface parameters,

Modbus – configuration of RS485 interface parameters,

Settings – settings: password, language, time, date,

Information – preview of program version, serial no., MAC address,

To enter from the **Measurement** mode into any mode, press and hold the button for about 3 seconds.

Use buttons to select the appropriate mode and accept with .

Return to the measuring mode is done by pressing at the same time .

Parametrs	Connection wire 3Ph-4W 3Ph-3W 1Ph-2W	Current range ⊗1 A ⊗5 A	Voltage L - N 057.7	Voltage L - L 100.0	VT primary 0000_100	VT secondary 00100.0	CT primary 00005	CT secondary 00005	Demand integ. time ⊗15 min ⊗30 min ⊗60 min	Avg synchronization none ⊗ with RTC
	Volt. Connector 2 ⊗ U1 ⊗ U2 ⊗ U3	Volt. connector 5 ⊗ U1 ⊗ U2 ⊗ U3	Volt. Connector 8 ⊗ U1 ⊗ U2 ⊗ U3	Curr connector 1-3 ⊗ I1 ⊗ -I1 ⊗ I2 ⊗ -I2 ⊗ I3 ⊗ -I3	Curr connector 4-6 ⊗ I1 ⊗ -I1 ⊗ I2 ⊗ -I2 ⊗ I3 ⊗ -I3	Curr connector 7-9 ⊗ I1 ⊗ -I1 ⊗ I2 ⊗ -I2 ⊗ I3 ⊗ -I3	Del energy counters ⊗ No ⊗ active ⊗ reactive ⊗ apparent ⊗ all	Del demand values ⊗ No ⊗ Yes	Set defaults ⊗ No ⊗ Yes	
Alarms	Settings	Logical conditions ⊗ C1 ⊗ C1vC2vC3 ⊗ C1^C2 ^C3 ⊗(C1 ^C2)vC3 ⊗(C1 vC2)^C3	RLY state if AL on. ⊗ off ⊗ on	Holdback alarm off ⊗ off ⊗ on	Disp. alarm event ⊗ off ⊗ on.	Set AL defaults ⊗ No ⊗ Yes				
Alarm 1										
Alarm 2	Condition C1	Values ⊗ U1 ⊗ I1 ⊗ P1 ⊗ Q1 ⋮ ⊗ gg:mm	Condition type ⊗ n_on ⊗ noFF ⊗ on ⊗ ofFF ⊗ H_on ⋮ ⊗ 3_oF	Lo limit condition[%] +0099.0	Hi limit condition [%] +0101.0	Delay condition on [s] 0000	Delay condition off [s] 0000	Hldbk cond. off->on [s] 0000	Display cond. event ⊗ off ⊗ On	
	Condition C2									
	Condition C3									

Fig.12a. Programming matrix

Displaying	Settings	Backlight ⊗ off ⊗ on	Backlight off time [s] 0000	Pages cfg 22 / 23 ⊗ Page 1 ⊗ Page 2 ⊗ Page 3 ⋮ ⊗ Page 23	Set page defaults ⊗ No ⊗ Yes
	Page 1 ⋮ Page 22	...\\Page 1 Display field 1 Display field 2 Display field. 3	...\\Display field 1 ⊗ Off ⊗ U1 ⊗ I1 ⊗ P1 ⋮ ⊗ En S		
		...\\Page 23 H03 U1 % I1 % U2 % I2 % U3 % I3 %			

Fig.12b. Programming matrix

Archiving	Group 1	Archive type	Parametrs	Trigger	Interval [s]	Archive low [%]	Archive high [%]
	Group 2	<ul style="list-style-type: none"> ⊕ n_on ⊖ noFF ⊖ on ⊖ off ⊖ H_on ⋮ ⊖ 3_oF 	<ul style="list-style-type: none"> ⊕ U1 ⊖ I1 ⊖ P1 ⊖ Q1 ⊖ S1 ⋮ ⊖ Kol. faz 	<ul style="list-style-type: none"> ⊕ U1 ⊖ I1 ⊖ P1 ⊖ Q1 ⊖ S1 ⋮ ⊖ gg:mm 	0001	+0000.0	+0000.0
	CSV Settings	Value separator <ul style="list-style-type: none"> ⊕ Comma ⊖ Semicolon ⊖ Tabulator 	Decimal separator	<ul style="list-style-type: none"> ⊕ Dot ⊖ Comma 			
	Actions	Copy arch. to CSV <ul style="list-style-type: none"> ⊕ No ⊖ Yes 	Clear archive	<ul style="list-style-type: none"> ⊕ Nie ⊖ Tak 			

Fig.12c. Programming matrix

Ethernet	Addresses	DHCP	Mode	IP address	Subnet mask	Gateway Address	DNS address	MAC address
	Obtained from DHCP or entered manually when DHCP is turned off							
	Modbus TCP	Address	Port	Connection limit	Waiting time [s]			
		001	00502	1	001			
	FTP	Command port	Data port					
		00021	01025					
	WWW	Port						
		00080						

Fig.12d. Programming matrix

Modbus	Address 001	Baudrate ❖ 4800 b/s ❖ 9600 b/s ❖ 19,2 kb/s ❖ 38,4 kb/s ❖ 57,6 kb/s ❖ 115,2 kb/s	Mode ❖ RTU 8N2 ❖ RTU 8N1 ❖ RTU 801 ❖ RTU 8N1	Set defaults 42xx ❖ Nie ❖ Tak	
Settings	Password ****	Language ❖ English ❖ Polski ❖ Deutsch	Time 13.47	Date 15/05/2018	Set all defaults ❖ No ❖ Yes
Information	Type NR30	Order code 1121	Boot version 1.06	Program version 0.80	Serial number 18040001 MAC address aa.bb.cc.00.21.01 DHCP ❖ off ❖ on Adres IP 000.000.000.000 Subnet mask 255.255.255.000 Gateway Address 000.000.000.000 DNS address Obtained from DHCP or entered manually when DHCP is turned off Service code 12A49AD32EF7C98A12BC

Fig.12e. Programming matrix

8.1 Measurement mode

In the **Measurement** mode, the values of quantities are displayed acc. to the pre-programmed or user-configured pages in the **Displaying** mode.

The change of the page is done by pressing (next page) or button (previous page). Pressing the button displays the minimum, maximum or current value (no symbol) of the displayed quantity. Resetting minimum values is done by brief pressing the button, and then ; resetting maximum values by pressing respectively and .

When displaying inductive or capacitive reactive power or energy, a marker is displayed that indicates the nature of the load "L" at inductive load or "C" at capacitive load.

When displaying active energy, the "+" sign displays active energy import or "-" active energy export.

Exceeding the upper or lower indication range is indicated on the display by or . When measuring averaged values (P DMD, S DMD, I DMD) single measurements are done with a 0.25 second quantum. Averaging time can be chosen: 15, 30 or 60 minutes. Until the time all averaged samples are obtained, the values are calculated from already measured samples.

The current in the neutral wire IN is calculated from phase current vectors.

	A1	1	2	3	A2	1	2	3	E	T
U1					103.	75			V	
U2					99.	234			V	
U3					101.	86			V	

Fig.13. Screen of the measuring mode of the meter

8.1.1 Measurement of voltage and current harmonics

The choice of harmonics is made by selecting page 23 dedicated to displaying harmonic values of voltages U₁, U₂, U₃ and currents I₁, I₂, I₃ simultaneously for 3-phases. The number of the displayed harmonic can be changed in the range 2..63 after pressing the button and then or .

H 05		M 0 0 E	
U ₁	3 . 28%	I ₁	4 . 17%
U ₂	1 . 42%	I ₂	2 . 38%
U ₃	2 . 35%	I ₃	3 . 42%

Fig.14 Screen 23 - visualization of harmonics

8.2 Parameters mode

This mode is used to set the meter parameters. To enter the Parameters mode, press the button for approx. 3 seconds, and then press the or select the Parameters mode and accept with the button .




Fig.15. Screen for selecting Parameters mode

for approx. 3 seconds, and then press the or select the Parameters mode and accept with the button . Access to configuration of parameters is protected by password, if it has been introduced and is different from zero. When the password is 0000, the password prompt is bypassed. If the password is incorrect, the message "Incorrect password" is displayed. Read-only menu." is displayed. Then you can view the parameters, but the changes are blocked.

When the password is valid or not entered, we can set values according to Table 1.

Using we select a parameter and confirm using the button . Then using we select the parameter feature or the desired parameter values are set. The active position is indicated by the cursor . The selected characteristic or value of the parameter should be confirmed by pressing the button or canceled by simultaneous pressing . To exit the Parameter procedure, press the button or wait for about 120 seconds. Exit the Parameters selection menu after pressing the button again or, after waiting for about 120 seconds.

Table 1

No.	Parameter name	Characteristic / value	Description	Default value
1	Connection wire	3Ph-4W 3Ph-3W 1Ph-2W	Network type 3 phase 4 wire 3 phase 3 wire 1 phase 2 wire	3Ph-4W
2	Current range	1A, 5A	Input range:1A or 5A	5A
3	Voltage L-N	57.7 .. 100.0 V; or	Phase input voltage	57.7 V or

		230.0 .. 400.0 V;		230.0 V
4	Voltage L-L	100.0 .. 170.0 V; or 400.0 .. 690.0 V;	Phase-to-phase input voltage	100.0 or 400.0
5	VT primary	1 .. 1245183 V	Primary voltage of transformer	100
6	VT secondary	0.1 .. 01000.0	Secondary voltage of transformer	100.0
7	CT primary	1...20000	Primary current of transformer	5
8	CT secondary	1...1000	Secondary current of transformer	5
9	Demand integ. time	15 min, 30 min, 60 min	Averaging time of active power P DMD, of apparent power S DMD, of current I Demand	15 min
10	AVG synchronization	none, with RTC	Averaging synchronized with real time clock	none
11	Volt. Connector 2	U1, U2, U3		U1
12	Volt. Connector 5	U1, U2, U3		U2
13	Volt. Connector 8	U1, U2, U3		U3
14	Curr connector 1-3	I1,-I1,I2,-I2,I3,-I3		I1
15	Curr connector 4-6	I1,-I1,I2,-I2,I3,-I3		I2
16	Curr connector 7-9	I1,-I1,I2,-I2,I3,-I3		I3
17	Del energy counters	No, active, reactive, apparent, all	Resetting watt-hour meters	No
18	Del demand values	No, Yes	Resetting averaged values	No
19	Set defaults param	No, Yes	Default settings of parameters	No

- During a parameter change, it is checked whether the value is within the range. In the case of setting the value out of range, the value is set to the maximum value (when the value is too high) or to the minimum value (when the value is too low).
- When changing the parameter "Voltage L - N", the parameter "Voltage L - L" is automatically converted ($\times \sqrt{3}$),
when changing the parameter "Voltage L - L", the parameter "Voltage L - N" is automatically converted ($\times \sqrt{3}$),

For the configuration of NR30 meters you can also use our free eCon software available at www.lumel.com.pl.

8.3 Alarm mode

Select the **Alarms** mode in options and approve the choice by pressing .




Fig.16. Alarm mode screens

Table 2

No.		Parameter name	range	Notes / description	Default value
1	Settings	Logical conditions	C1 C1 v C2 v C3 C1 \wedge C2 \wedge C3 (C1 \wedge C2) v C3 (C1 v C2) \wedge C3		C1
2		RLY state if AL on	on/off	State of relay with activated alarm Deactivated/Activated	on
3		Holdback alarm off	on/off	Lock of alarm deactivation	off
4		Disp. alarm event	on/off	When the function of alarm signaling is switched on, then after the state of emergency the alarm symbol is not blanked, but it begins to flash. The signaling lasts until pressing the buttons The function only applies to the alarm signaling, thus relay contacts will act without maintaining, according to the selected type of alarm.	off
5		Set AL defaults	No / Yes	Default settings of parameters	No
6		Values	U1,I1,P1,Q1,...,gg:mm	Value at the alarm output, parameter acc. to table 7	U1
7	Condition C1	Condition type	n_on, noFF, on, oFF, H_on, HoFF, 3non, 3noF, 3_on, 3_of	acc. to Fig. 17	n-on
8	Condition C2	Lo limit condition	-144.0...144.0	Lower value of condition in % of the nominal value of input quantity acc. to table 7	99.0

9	Hi limit condition	-144.0...144.0	Upper value of condition in % of the nominal value of input quantity acc. to table 7	101.0
10	Delay condition on	0 ... 3600	Delay of condition act. in seconds	0
11	Delay condition off	0 ... 3600	Delay of condition deactivation in seconds	0
12	Hldbk cond. off->on	0 ... 3600	Locking the condition reactivation in seconds	0
13	Display cond. event	On/off	Signaling of condition occurrence When the function of maintaining is switched on, after the state of condition is finished, the condition symbol is not blanked, but it begins to flash. The signaling lasts until pressing the buttons  	off

When the entered "Upper condition value " is lower than the "Lower condition value ", the condition is disabled.




Fig.17. Types of conditions: a) n_on b) noFF c) on d) OFF

Other types of conditions:

- **H_on** – always met;
- **HoFF** – always not met,
- **3non** – when the value of the measured quantity exceeds the "Upper value of condition" at any phase - the condition will be met. The condition is disabled when the value of the measured value at all phases is less than the "Lower value of the condition."
- **3noF** – when the value of the measured quantity is lower than the "Lower value of condition" at any phase - the condition will be met. The condition is disabled when the value of the measured value at all phases is higher than the "Upper value of the condition."
- **3_on** – when the value of the measured quantity at any phase will be between the "Lower value of condition," and "Upper value of condition" - the condition is met. The condition will be disabled if the value of the measured quantity is below the "Lower value of condition" or above the

"Upper value of the condition" at all phases.

- **3_oF** – when the value of the measured quantity will be below the "Lower value of condition" or above the "Upper value of condition" at any phase - the condition is met. The condition will be disabled if the value of the measured quantity is between the "Lower value of condition" and the "Upper value of the condition" at all phases.
- In the 3rd series of alarms the alarm value must come from the following ranges: 01-09, 10-18 and 19-27 (acc. to table 7). They work with the same Hysteresis thresholds of the "Lower values of condition" and "Upper value of condition" for each phase. The blanking of alarm signaling occurs after simultaneous pressing of the buttons .

8.4 Display mode

In this mode, we configure the pages displayed in the normal operation mode of the meter Measurement,




Fig.18. Ethernet mode screens

Table 3

No.		Parameter name	range	Notes / description	Default value
1	Settings	Backlight:	On, off	Display backlit Off- Disabled On- Enabled	on
		Backlight off time	0 .. 9999	Backlight shutdown time in seconds	0
		Pages cfg	23 / 23 Page 1 Page 2 : Page 11 Page 23*	Selection of pages visualized in Measurement mode.	Page 1 Page 2 : Page 11 Page 23
		Set page defaults	No Yes	Default settings of pages	No
4	Page 1 : :	Display field 1 Display field 2	Off U1 I1	Selection of quantities displayed on	Table 5a or 5b or 5c

	Page 22	Display field 3	P1 Q1 : En S	a chosen page and field in accordance with table 4.	depending on connections layout
--	---------	-----------------	-----------------------	---	---------------------------------

*Page 23 is dedicated to displaying the harmonics values of voltages U1, U2, U3 and currents I1, I2, I3 and it is not possible to change the quantity in the selected field. The page can be turned off from the preview: "Settings ->Page Selection".

Selection of the displayed quantities:

Table 4

No.	quantity name	designation	unit	Signaling	3Ph / 4W	3Ph / 3W	1Ph / 2W
00	no quantity - display field is blank	Off			✓	✓	✓
01	voltage of L1 phase	U1	(M,k)V		✓	x	✓
02	current in phase wire L1	I1	(k)A		✓	✓	✓
03	active power of L1 phase	P1	(G,M,k)W		✓	x	✓
04	reactive power of L1 phase	Q1	(G,M,k)var	L/C	✓	x	✓
05	apparent power of L1 phase	S1	(G,M,k)VA		✓	x	✓
06	active power factor of L1 phase (PF1=P1/S1)	PF1			✓	x	✓
07	tgφ factor of L1 phase (tg1=Q1/P1)	tg1			✓	x	✓
08	THD of L1* phase voltage	THD U1	%		✓	✓	✓
09	THD of L1 phase current	THD I1	%		✓	✓	✓
10	voltage of L2 phase	U2	(M,k)V		✓	x	x
11	current in phase wire L2	I2	(k)A		✓	✓	x
12	active power of L2 phase	P2	(G,M,k)W		✓	x	x
13	reactive power of L2 phase	Q2	(G,M,k)var	L/C	✓	x	x
14	apparent power of L2 phase	S2	(G,M,k)VA		✓	x	x
15	active power factor of L2 phase (PF2=P2/S2)	PF2	PF		✓	x	x
16	tgφ factor of L2 phas (tg2=Q2/P2)	tg2			✓	x	x
17	THD of L2* phase voltage	THD U2	%		✓	✓	x
18	THD of L2 phase current	THD I2	%		✓	✓	x
19	voltage of L3 phase	U3	(M,k)V		✓	x	x
20	current in phase wire L3	I3	(k)A		✓	✓	x
21	active power of L3 phase	P3	(G,M,k)W		✓	x	x
22	reactive power of L3 phase	Q3	(G,M,k)var	L/C	✓	x	x
23	apparent power of L3 phase	S3	(G,M,k)VA		✓	x	x
24	active power factor of L3 phase (PF3=P3/S3)	PF3			✓	x	x
25	tgφ factor of L3 phase (tg3=Q3/P3)	tg3			✓	x	x
26	THD of L3* phase voltage	THD U3	V%		✓	✓	x
27	THD of L3 phase current	THD I3	A%		✓	✓	x
28	average phase voltage	U avg	(M,k)V		✓	x	x
29	average three-phase current	I avg	(k)A		✓	✓	x
30	three-phase active power	ΣP	(G,M,k)W	+/-	✓	✓	✓

31	three-phase reactive power	ΣQ	(G,M,k)var	L/C	✓	✓	✓
32	three-phase apparent power	ΣS	(G,M,k)VVA		✓	✓	✓
33	active power factor 3-phase (PF=P/S)	PF avg			✓	✓	x
34	tgφ factor 3-phase average (tg=Q/P)	tg avg			✓	✓	x
35	THDU 3-phase average*	THD U	%		✓	✓	x
36	THDI 3-phase average	THD I	%		✓	✓	x
37	Frequency	f	Hz		✓	✓	✓
38	phase-to-phase voltage L1-L2	U12	(M,k)V		✓	✓	x
39	phase-to-phase voltage L2-L3	U23	(M,k)V		✓	✓	x
40	phase-to-phase voltage L3-L1	U31	(M,k)V		✓	✓	x
41	phase-to-phase average voltage	U123	(M,k)V		✓	✓	x
42	averaged active power (P Demand)	P DMD	(G,M,k)W		✓	✓	✓
43	averaged apparent power (S Demand)	S DMD	(G,M,k)VVA		✓	✓	✓
44	averaged current (I Demand)	I DMD	(k)A		✓	✓	✓
45	current in neutral wire	I(N)	(k)A		✓	x	x
46	3-phase imported active energy	En P+	kWh		✓	✓	✓
47	3-phase exported active energy	En P-	kWh		✓	✓	✓
48	3-phase reactive inductive energy	En Q ind	kvarh		✓	✓	✓
49	3-phase reactive capacitive energy	En Q cap	kvarh		✓	✓	✓
50	3-phase apparent energy	En S	kVAh		✓	✓	✓

* In 3-phase 3-wire system (3Ph/3W) respectively THD U12, THD U23, THD U31, THD U123

Default settings of the displayed pages in 3-phase 4-wire system Table 5a

P1	P2	P3	P4	P5	P6	P7	P8	P9	P10						
U1 V	U12 V	I1 A	P1 W	Q1 var	PF1	tg1	ΣP W	U avg V	PF avg						
U2 V	U23 V	I2 A	P2 W	Q2 var	PF2	tg2	ΣQ var	I avg A	tg avg						
U3 V	U31 V	I3 A	P3 W	Q3 var	PF3	tg3	ΣS VA	I(N) A	f Hz						
P11	P12	P13	P14	P15	P16	P17	P18	P19	P20						
U1 V	Q1 var	U2 V	Q2 var	U3 V	Q3 var	P DMD W	ΣP W	ΣQ var	ΣS VA						
I1 A	S1 VA	I2 A	S2 VA	I3 A	S3 VA	S DMD W	+En P kWh	EnQ L kvarh	En S kVAh						
P1 W	PF1	P2 W	PF2	P3 W	PF3	I DMD A	-En P kWh	EnQ C kvarh	f Hz						
P21	P22	P23 (harm.2..63)													
THD U1 %	THD I1 %	U1 % I1 %													
THD U2 %	THD I2 %	U2 I2 ...													
THD U3 %	THD I3 %	U3 I3 ...													

Default settings of the displayed pages in 3-phase 3-wire system Table 5b

P1	P2	P3	P4	P5	P6	P7	P8	P9	P10
U12 V	I1 A	U123 V	ΣP W	PF avg	P DMD W	ΣP W	ΣQ var	THD U12 %	THD I1 %
U23 V	I2 A	I avg A	ΣQ var	tg avg	S DMD W	En P+ kWh	En Q L kvarh	THD U23 %	THD I2 %
U31 V	I3 A	f Hz	ΣS VA	f Hz	I DMD A	En P- kWh	En Q C kvarh	THD U31 %	THD I3 %

Default settings of the displayed pages in 1-phase system Table 5c

P1	P2	P3	P4	P5	P6
U1 V	P1 W	PF1	P DMD W	P1 W	Q1 var
I1 A	Q1 var	tg1	S DMD W	En P+ kWh	En Q L kvarh
f Hz	S1 VA	f Hz	I DMD A	En P- kWh	En Q C kvarh

8.5 Archiving mode

Select the **Archiving** mode in options and confirm the choice by pressing .

Using   we select a parameter and confirm using the button . Then using   we select the parameter feature or the desired parameter values are set. The active position is indicated by the cursor . The selected characteristic or value of the parameter should be confirmed by pressing the button  or canceled by simultaneous pressing  . The choice of parameters (archived quantities) is made in the menu:

Archiving \ Group1 \ Parameters by selecting or deselecting the archived size by briefly pressing .

Acceptance of selected archived quantities is done by pressing  for at least 3 seconds. The same applies to the selection of parameters (archived quantities) for Group2.

To exit Archiving procedure, press   again or after waiting for approx. 120 seconds. Exit the Parameters selection menu after pressing the button again

  or, after waiting for about 120 seconds.




Fig.19. Archiving mode screens

Table 6

No.		Parameter name	range	Notes / description	Default value
1	Group 1 Group 2	Archive type	n_on, noFF, on,oFF, H_on, HoFF, 3non, 3noF, 3_on, 3_oF	Archiving type - archiving activation condition acc. to Fig.20	n_on
2		Parameters	U1, I1, P1, ... sequence of phases	Archived quantities acc. to table 7	
3		Trigger	U1, I1, P1, ... hh:mm	Value triggering archiving.	U1
4		Interval	0 ... 3600 s	Archiving time in seconds	1 s
5		Archive low	-144.0 .. +144.0	Archiving lower threshold in % of the nominal value of triggering quantity acc. to table 7	0.0%
6		Archive high	-144.0 .. +144.0	Archiving upper threshold in % of the nominal value of triggering quantity acc. to table 7	0.0%
7	CSV settings	Value separator	Comma, semicolon, tabulator	CSV file format settings in the file archive	Comma
8		Decimal separator	Dot, Comma		Dot
9	Actions	Copy arch. to CSV	No, Yes	copying the internal memory to the file archive	No
10		Clear archive	No, Yes		No

Entering the value "Archive high" less than or equal to "Archive low" disables the recording. Not applicable to H_on mode.




Fig.20. Types of archiving: a) n_on b) noFF c) on d) oFF

Other archiving types:

- **H_on** – always enabled;
- **HoFF** – always disabled,
- **3non** – when the condition n_on type is met at any phase - archiving is enabled. It will be disabled only when all trigger conditions disappear.
- **3noF** – when the condition noFF type is met at any phase - archiving is enabled. It will be disabled only when all trigger conditions disappear.
- **3_on** – when the condition on type is met at any phase - archiving is enabled. It will be disabled only when all trigger conditions disappear.
- **3_oF** – when the condition oFF type is met at any phase - archiving is enabled. It will be disabled only when all trigger conditions disappear.
- In the series 3 archiving the triggering quantity must come from the following range: 01-09 (according to table 7). Archiving works with the same hysteresis thresholds Ar_L and Ar_H for each phase.

Selection of quantities at alarm and archived outputs:

Table 7

Value in registers	Parameter	Type of quantity	Value for percentage calculations corresponding to 100 % of the nominal range.
01	U1	voltage of L1 phase	Un [V] *
02	I1	current in phase wire L1	In [A] *
03	P1	active power of L1 phase	Un x In x cos(0°) [W] *
04	Q1	reactive power of L1 phase	Un x In x sin(90°) [Var] *
05	S1	apparent power of L1 phase	Un x In [VA] *
06	PF1	power factor PF of L1 phase	1
07	tg1	tgφ coefficient of phase L1	1
08	THD U1	THD of L1 phase voltage**	100.00 [%]
09	THD I1	THD of L1 phase current	100.00 [%]
10	U2	voltage of L2 phase	Un [V] *
11	I2	current in phase wire L2	In [A] *
12	P2	active power of L2 phase	Un x In x cos(0°) [W] *
13	Q2	reactive power of L2 phase	Un x In x sin(90°) [Var] *
14	S2	apparent power of L2 phase	Un x In [VA] *

15	PF2	power factor PF of L2 phase	1
16	tg2	tg φ coefficient of phase L2	1
17	THD U2	THD of L2 phase voltage**	100.00 [%]
18	THD I2	THD of L2 phase current	100.00 [%]
19	U3	voltage of L3 phase	Un [V] *
20	I3	current in phase wire L3	In [A] *
21	P3	active power of L3 phase	Un x In x cos(0°) [W] *
22	Q3	reactive power of L3 phase	Un x In x sin(90°) [Var] *
23	S3	apparent power of L3 phase	Un x In [VA] *
24	PF3	power factor PF of L3 phase	1
25	tg3	tg φ coefficient of phase L3	1
26	THD U3	THD of L3 phase voltage**	100.00 [%]
27	THD I3	THD of L3 phase current	100.00 [%]
28	U avg	average phase voltage	0.00 [%]
29	I avg	average three-phase current	In [A] *
30	ΣP	3-phase active power (P1+P2+P3)	3 x Un x In x cos(0°) [W] *
31	ΣQ	3-phase reactive power (Q1+Q2+Q3)	3 x Un x In x sin(90°) [Var] *
32	ΣS	3-phase apparent power (S1+S2+S3)	3x Un x In [VA] *
33	PF avg	3-phase power factor PF	1
34	tg avg	3-phase tg φ coefficient	1
35	THD U	THD of voltage 3-phase**	100.00 [%]
36	THD I	THD of current 3-phase	100.00 [%]
37	f	frequency	100 [Hz]
38	U12	phase-to-phase voltage L1-L2	$\sqrt{3}Un$ [V] *
39	U23	phase-to-phase voltage L2-L3	$\sqrt{3}Un$ [V] *
40	U31	phase-to-phase voltage L3-L1	$\sqrt{3}Un$ [V] *
41	U123	phase-to-phase average voltage	$\sqrt{3}Un$ [V] *
42	P DMD	averaged active power (P Demand)*	3 x Un x In x cos(0°) [W] *
43	S DMD	averaged apparent power (S Demand)*	3 x Un x In [VA] *
44	I DMD	averaged current (I Demand)*	In [A] *
45	I(N)	current in neutral wire	In [A] *
46	En P+	3-phase imported active energy	100000 [kWh]
47	En P-	3-phase exported active energy	100000 [kWh]
48	En Q ind	3-phase reactive inductive energy	100000 [kvarh]
49	En Q cap	3-phase reactive capacitive energy	100000 [kvarh]
50	En S	3-phase apparent energy	100000 [kVAh]
51	Sequence of phases	Sequence of phases	L1,L2,L3 - 0,00 [%] L1,L3,L2 - 100,00 [%]
52	hh:mm	time, hhx100+mm	2400 - 100 [%]

*Un - voltages nominal values defined with "Voltage L-N" parameter acc. to table 1

*In - currents nominal values

* In 3-phase 3-wire system (3Ph/3W) respectively THD U12, THD U23, THD U31, THD U123

***Parameter is not included in the archived parameters

16 out of 51 parameters (bits from 1 to 51 of registers 4106...4109 and 4115...4118) can be selected for recording in each group. Bit set as "1" adds parameter for recording, set as "0" deletes. It is possible to set all 51 bits, but only first 16 bits set as "1" will be included into recording.

8.6 Ethernet mode

Select the **Ethernet** mode in options and approve the choice by the  push-button.




Fig.21. Ethernet mode screen

Table 8

No.		Parameter name	range	Notes / description	Default value
1	Address es	DHCP	Off/on	Enabling/Disabling DHCP Client (service of automatic acquiring of the meter Ethernet IP protocol parameters from External DHCP Servers within the same Local Area Network)	off
2		Mode	Auto, 10Mb/s, 100Mb/s		Auto
3		IP Address	0.0.0.0...255.255.255.255	10.0.1.161	-
4		Subnet mask	0.0.0.0...255.255.255.255	255.0.0.1	-
5		Default gate	0.0.0.0...255.255.255.255	0.0.0.0	-
6		Gateway Address	0.0.0.0...255.255.255.255	10.0.0.44	-
7		MAC Address		Acquired from DHCP or entered manually when DHCP is deactivated.	-
8	Modbus TCP	Address	1 ... 247		1
9		Port	80 ... 32000		1
10		Connection limit	1 ... 4		1
11		Waiting time	10 .. 360		60s
12	FTP	Command port	20 ... 32000		21
13		Data port	20 ... 32000		1025
14	WWW	Port	80 ... 32000		80

8.7 Modbus mode

Select the **Modbus** mode in options and approve the choice by the  push-button.




Fig.22. Modbus mode screen

Table 9

No.	Parameter name	Characteristic / value	Description	Default value
1	Address	1...247	Address on the Modbus network.	1
2	Baudrate	4800 b/s, 9600 b/s, 19,2 kb/s, 38,4 kb/s, 57,7 kb/s, 115,2 kb/s	Baud rate	9600 b/s
3	Mode	RTU 8N2, RTU 8N1, RTU 8O1, RTU 8N1	Transmission mode	RTU 8N2
4	Set defaults 42xx	No, Yes	Programmable read-only register group	No

8.8 Settings mode

Select the **Settings** mode in options and approve the choice by the  push-button.




Fig.23. Settings mode screen

Table 10

No.	Parameter name	Characteristic / value	Description	Default value
1	Password	0 ... 9999	0 - off	0
2	Language	English, Polish, Deutsch		English
3	Time	hh:mm	hour:minute	00:00:00
4	Date	dd/mm/yyyy	Day/month/year	15.05.2018
5	Set all defaults	No, Yes		No

8.9 Information mode

Select the **Information** mode in options and approve the choice by the  push-button.



Fig.24. Information mode screen

Table 11

No.	Parameter name	Characteristic / value	Description	Default value
1	Type		Type of meter	NR30
2	Order code		First 5 digits of ordering code	e.g.12200
3	Boot version		Loader version	e.g.1.04
4	Program Version		Version of the main meter program	e.g.0.60
5	Serial Number	ddmmxxxx	Current serial number of the meter day month current number	np.15070006
6	MAC Address	xx:xx:xx:xx:xx:xx	48-bit hardware address of the Ethernet interface written in hexadecimal	e.g.64:0E:0D:0C:0B:0A
7	DHCP	Off-on	Enabling/disabling DHCP client (the service of automatic acquiring the parameters of Ethernet interface IP protocol of the meter from external DHCP servers located within the same LAN network).	off
8	IP Address	0.0.0.0...255.255.255.255	10.0.1.161	Acquired from DHCP or entered manually when deactivated
9	Subnet mask	0.0.0.0...255.255.255.255	255.0.0.1	
10	Gateway Address	0.0.0.0...255.255.255.255	0.0.0.0	
11	DNS Address	0.0.0.0...255.255.255.255	10.0.0.44	
12	Service code	e.g.: 12A49AD32EF7C98A12BC	20 character code enabling extended functionality	-

9 EXTENDED FUNCTIONALITY

In the NR30 meter (for additional payment) you can activate additional functionality. This is done by entering, from the meter menu level (Information → Service code), the correct code received from the manufacturer. A detailed description of the additional functions and their activation can be found in the appropriate manuals on the manufacturer's website.

10 MEASURED VALUES ARCHIVING

10.1 INTERNAL MEMORY

NR30 meters are equipped with 4MB internal memory and 8GB file archive memory designed for storing data recorded by the meter. The 4MB internal memory allows for storage of 40960 records. The memory is a circular buffer.

10.2 COPYING THE ARCHIVE

Once the 4MB internal memory is full in 70% or forced at any time: in the **Archiving** mode, select **Actions** and set the "Copy archive to CSV file" parameter to "Yes". The recorded data will be copied to the file archive. Starting the copying procedure to the archive can also be done via the RS485 interface (register 4125).

Example: file archive with an archiving period of 5 sec. allows you for recording for about 2 years. The status of the file archive usage can be checked in Status 3 (see: Status register 3 (address 7561)).

When the file archive is full to 95%, the overwrite mode is started, in which during further archiving and creating new archive files, the oldest archived files are deleted.

When the file archive is full (less than 14 days to fill the file archive at 1 second intervals), the F flag starts flashing along with the percentage of the file archive usage.

When copying internal memory, the NR30 meter creates catalogs and files in the file archive. An example of the directory structure is shown in Fig. 25.

Nazwa pliku	Rozmiar pliku	Typ pliku	Data modyfikacji	Prawa dost...	Właściciel/...
16132711.CSV	4 059 617	OpenOffic...	2014-12-17	-r--r--r--	0 0
17075806.CSV	471 087	OpenOffic...	2014-12-17	-r--r--r--	0 0
17081955.CSV	290 929	OpenOffic...	2014-12-17	-r--r--r--	0 0
17083224.CSV	211 927	OpenOffic...	2014-12-17	-r--r--r--	0 0

4 pliki. Całkowity rozmiar: 5 033 560 bajtów

Fig.25. Directory structure in the file archive

Data in the archives are stored in files placed in directories (year, month of archive copy). File names are marked as the day and time of copying the first record and have the format ddhhmmss.csv, where: dd-day, hh-hour, mm -minute, ss-second.

10.3 STRUCTURE OF ARCHIVE FILES

Files containing archived data have the structure of columns, where subsequent columns of data are separated by a comma. The first line of the file contains the column header. Data records are arranged in rows in succession. The view of the sample file is shown in Figure 26.

Plik	Edycja	Format	Widok	Pomoc
date,time,record index,block,register1,name1,value1,..,register16,name16,value16				
2014-12-17,08:32:24,0000512808,0,7500, U_1,2,237693E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:25,0000512809,0,7500, U_1,2,237693E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:26,0000512810,0,7500, U_1,2,240464E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:27,0000512811,0,7500, U_1,2,241046E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:28,0000512812,0,7500, U_1,2,243908E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:29,0000512813,0,7500, U_1,2,240464E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:30,0000512814,0,7500, U_1,2,243908E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:31,0000512815,0,7500, U_1,2,241046E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:32,0000512816,0,7500, U_1,2,246347E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:33,0000512817,0,7500, U_1,2,246347E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:34,0000512818,0,7500, U_1,2,244283E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:35,0000512819,0,7500, U_1,2,244283E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:36,0000512820,0,7500, U_1,2,243908E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:37,0000512821,0,7500, U_1,2,246347E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:38,0000512822,0,7500, U_1,2,246347E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:39,0000512823,0,7500, U_1,2,246523E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:40,0000512824,0,7500, U_1,2,246523E+02,..,7519, I_3,0.000000E+00				
2014-12-17,08:32:41,0000512825,0,7500, U_1,2,244662E+02,..,7519, I_3,0.000000E+00				

Fig.26. Sample archive file with data

Subsequent fields included in the row describing the record have the following meaning:

- date – the date of the data registration, the date separator character is "-"
- time – hour, minute, second of recorded data, the time separator is ":"
- record index – the unique index of the record. Each record has its own individual number. This number increases when more records are recorded.
- block – reserved,
- register1 – Modbus register address of the first archived value,
- name1 – description of the Modbus register of the first archived value,
- value1 – the first archived value. The decimal separator is ".", The values are saved in the engineering format.
- :
- register16 – Modbus register address of the sixteenth archived value,
- name16 – Modbus register description of the sixteenth archived value,
- value16 – the sixteenth archived value. The decimal separator is ".", The values are saved in the engineering format.

name1, ...,name16 – description in accordance with table 8 (Displayed parameter).

10.4 DOWNLOADING THE ARCHIVE

Archived data can be downloaded via Ethernet using the FTP protocol.

11 SERIAL INTERFACES

11.1 RS485 INTERFACE – the list of parameters

The implemented protocol is in accordance with the PI-MBUS-300 Rev G of Modicon Company. The list of serial link parameters of NR30 meter:

- | | |
|--------------------|---|
| • ID | 0xE6 |
| • meter address | 1..247, |
| • baud rate | 4.8, 9.6, 19.2, 38.4, 57.6, 115.2 kbit/s, |
| • operation mode | Modbus RTU, |
| • information unit | 8N2, 8E1, 8O1, 8N1, |

- maximum time to commence the response 600 ms,
- maximum number of read registers in one query
 - 61 registers – 4 byte,
 - 122 registers – 2 byte,
 - 03, 04, 06, 16, 17,
 - 03, 04 registers reading,
 - 06 one register record
 - 16 n - registers record,
 - 17 device identification
- implemented functions

Default settings: address 1, baud rate 9.6 kbit/s, RTU 8N2 mode,

11.2 Examples of registers reading and saving

Readout of n-registers (code 03h)

Example 1. Readout of 2 16-bit registers of integer type, starting with the register addressed 0FA0h (4000) - registers values 10, 100.

Request:

Device address	Function	Register address		Number of registers		Checksum CRC
		B1	B0	B1	B0	
01	03	0F	A0	00	02	C7 3D

Response:

Device address	Function	Number of bytes	Value from the register 0FA0 (4000)		Value from register 0FA1 (4001)		Checksum CRC
			B1	B0	B1	B0	
01	03	04	00	0A	00	64	E4 6F

Example 2. Readout of 2 32-bit registers of float type as a combination of 2 16-bit registers starting with the register addressed 1B58h (7000) - registers values 10, 100.

Request:

Device address	Function	Register address		Number of registers		Checksum CRC
		B1	B0	B1	B0	
01	03	1B	58	00	04	C3 3E

Response:

Device address	Function	Number of bytes	Value from the register 1B58 (7000)		Value from the register 1B59 (7001)		Value from the register 1B5A (7002)		Value from the register 1B5B (7003)		Checksum CRC
			B3	B2	B1	B0	B3	B2	B1	B0	
01	03	08	41	20	00	00	42	C8	00	00	E4 6F

Example 3. Readout of 2 32-bit registers of float type as a combination of 2 16-bit registers starting with the register addressed 1770h (6000) - registers values 10, 100.

Request:

Device address	Function	Register address		Number of registers		Checksum CRC
		B1	B0	B1	B0	
01	03	17	70	00	04	4066

Response:

Device address	Function	Number of bytes	Value from the register 1770h(6000)		Value from the register 1770h(6000)		Value from the register 1772h(6002)		Value from the register 1772h(6002)		Checksum CRC
			B1	B0	B3	B2	B1	B0	B3	B2	
01	03	08	00	00	41	20	00	00	42	C8	E4 6F

Example 4. Readout of 2 32-bit registers of float type, starting with the register addressed 1D4Ch (7500)

- register values 10, 100.

Request:

Device address	Function	Register address		Number of registers		Checksum CRC
		B1	B0	B1	B0	
01	03	1D	4C	00	02	03 B0

Response:

Device address	Function	Number of bytes	Value from the register 1D4C (7500)				Value from register 1D4D (7501)				Checksum CRC
			B3	B2	B1	B0	B3	B2	B1	B0	
01	03	08	41	20	00	00	42	C8	00	00	E4 6F

Readout of single register (code 06h)

Example 5. Record of 543 (0x021F) value to register 4000 (0x0FA0)

Request:

Device address	Function	Register address		Register value		Checksum CRC
		B1	B0	B1	B0	
01	06	0F	A0	02	1F	CA 54

Response:

Device address	Function	Register address		Register value		Checksum CRC
		B1	B0	B1	B0	
01	06	0F	A0	02	1F	CA 54

Saving to n-registers (code 10h)

Example 6. Readout of 2 registers, starting with the register addressed 0FA3h (4003)

Recording values 20, 2000.

Request:

Device address	Function	Address of reg.Hi	Address of reg.Lo	No. of reg. Hi	No. of reg. Lo	Number of bytes	Value for reg. 0FA3 (4003)	Value for reg. 0FA4 (4004)	Checksum CRC
							B1	B0	
01	10	0F	A3	00	02	04	00	14	07 D0 BB 9A

Response:

Device address	Function	Register address		Number of registers		Checksum CRC
		B1	B0	B1	B0	
01	10	0F	A3	00	02	B2 FE

Report identifying the device (code 11h)

Example 7. Device identification

Request:

Device address	Function	Checksum
01	11	C0 2C

Response:

Address	Function	Number of bytes	ID	Device state	Information field for device software version (e.g. "NR30-0.80 - NR30 device with software version 0.80)	Checksum (CRC)
01	11	19	E6	FF	NR30-0.80 4E 52 33 30 2D 30 2E 38 30	20 20 20 20 20 20 20 20 20 20 20 20 20 20

11.3 Ethernet 10/100-BASE-T

NR30 meters are equipped with Ethernet interface that allows for connection of the meter (using RJ45 socket) to a local or global network (LAN or WAN). Ethernet interface allows to use network services implemented in the meter: WWW server, FTP server, Modbus TCP/IP. To use the network services of the meter, you need to configure the parameters from the meter Ethernet group. Standard Ethernet

parameters of the meter are shown in table 8. The basic parameter is the IP address of the meter - e.g. by default 10.0.1.161, which must be unique within the network to which we connect the device. The IP address can be assigned to the meter automatically by DHCP server present on the network provided that the option to acquire IP address from DHCP server is enabled in the meter. Ethernet → Addresses→ DHCP→ Enabled. If DHCP service is disabled then the meter will work with the default IP address allowing the user to change the IP address, e.g. from the meter menu. The Ethernet parameters of the meter can also be changed via the serial interface. Then the approval of changes is required by entering value "1" to the register 4149. After the changes are applied, the Ethernet interface is re-initialized according to the new parameters - all Ethernet interface services will be restarted.

11.3.1 Connection of 10/100 BASE-T interface

To access the Ethernet services, it is required to connect the meter to the network via the RJ45 slot located at the rear/ inside the panel part of the meter, operating in accordance with TCP/IP protocol.

Description of RJ45 socket LEDs function:

- yellow LED - illuminates when the meter is properly connected to the Ethernet network 100 Base-T, does not light up when the meter is not connected to the network or is connected to 10-Base-T network.
- green LED - Tx/Rx illuminates when the meter sends and receives data, flickers irregularly, when no data is transmitted the LED lights up permanently

In order to connect the meter to the network the user should use twisted pair cable.

- U/FTP – twisted pair cable with each pair foiled,
- F/FTP – twisted pair cable with each pair foiled, additionally cable with foil shield,
- S/FTP (formerly SFTP) – twisted pair cable with each pair foiled, additionally cable with wire mesh shield,
- SF/FTP (formerly S-STP) – twisted pair cable with each pair foiled, additionally with foil and wire mesh shield,

Categories of twisted pair cable according to the European standard EN 50173 minimum: Class D (category 5) - for high-speed local area networks, includes applications using the frequency band up to 100 MHz. For Ethernet interface the user should use twisted pair cable of STP type (shielded) category 5 with RJ-45 connector with conductors colors (in accordance with the colors described in table 11) acc. to the following standard:

- EIA/TIA 568A for both connectors at the so-called simple connection of NR30 to the network hub or switch,
- EIA/TIA 568A for the first connector and EIA/TIA 568B for the second connector at the so-called patch cord connection (crossover) used, among others, when connecting NR30 to the computer.

Table 12

Conductor no.	Signal	Conductor color acc. to standard	
		EIA/TIA 568A	EIA/TIA 568B
1	TX+	white-green	white-orange
2	TX-	green	orange
3	RX+	white-orange	white-green
4	EPWR+	blue	blue
5	EPWR+	white-blue	white-blue
6	RX-	orange	green
7	EPWR-	white-brown	white-brown
8	EPWR-	brown	brown




Fig.27 View and numbering of RJ45 slot pins

11.3.2 Web server

NR30 meter provides its own Web server that allows remote monitoring of measured values and readout of the meter status. With the web page the user can:

- obtain device information (serial number, execution code, firmware version, bootloader version, variant (standard or special),
- preview of the current measurement values, readout of the device status,
- select the language for the Web page,

Access to the Web server is achieved by entering the meter IP address in the web browser, e.g.: <http://192.168.1.030> (where 192.168.1.030 is the set address of the meter). The standard port for web server is port "80". Server port may be changed by the user.

Caution: For proper web page operation a browser with JavaScript enabled and compatible with XHTML 1.0 is required (all popular browsers, Internet Explorer, version 8 minimum).

11.3.2.1 General view




Fig.28. View of the meter WWW page

11.3.2.2 Selection of Web server user

The meter has two user accounts for the WWW server secured by individual passwords:

- user: "**admin**", password: "**admin**" - access to configuration and the preview of parameters
- user: "**user**", password: "**pass**" - access to the preview of parameters only.

Calling the meter IP address in the browser, for example <http://192.168.1.30> will show the start window in the browser where the user must enter the name and password.




Fig.29. View of the meter WWW server log window

Web server user names cannot be changed. However, it is possible to change the password for each user - it is recommended to change passwords for security reasons. Password change is only possible through the web page in "Ethernet" parameters group. Passwords can have a maximum of 8 characters. If the password is lost - which will prevent you from using the web server, you must restore the Ethernet interface parameters e.g. from the menu: Settings → Factory settings → Yes, or by entering the value of "1" in register 4152. All standard parameters of the meter including the Ethernet parameters (according to Table 9) and user passwords for WWW server will be restored:

user "**admin**" → password: "**admin**" ;
 user "**user**" → password "**pass**".

11.3.3 FTP server

FTP file sharing protocol is implemented in NR30 meters. The meter acts as a server, allowing clients to access the internal memory of the meter file system. Access to files is possible using a computer, tablet with installed FTP client or another device acting as FTP client. To transfer files using FTP the following ports are normally used: "1025" - data port and "21" - command port. If necessary, the user can change the port used by the FTP. Please note, that the configuration of the server and FTP client ports must be the same.

FTP client program can work in passive mode. In passive mode the connection is established fully by the client (the client chooses the data port). For file transfer with the meter it is possible to use maximum one connection at the same time, that is why the maximum number of connections must be limited to "1" in the client program.

11.3.3.1 Selection of FTP user

The meter has two user accounts for the FTP server secured by individual passwords:

- user: "**admin**", password: "**admin**" - access to files saving and reading
- user: "**user**", password: "**passftp**" - access to archive files reading only.


FTP user names cannot be changed, however it is possible to change the password for each user - it is recommended to change passwords for security reasons. Password change is only possible through the web page in "Ethernet" parameters group. Passwords can have a maximum of 8 characters. If the

password is lost - which will prevent you from using the FTP server, you must restore the Ethernet interface default parameters e.g. from the menu: Settings → Factory settings → Yes, or by entering the value of "1" in register 4152. All standard parameters of the meter including the Ethernet parameters (according to Table 9) and user passwords for FTP server will be restored:

user "**admin**" → password: "**admin**" ;

user "**user**" → password "**passftp**".

FileZilla can be used as the FTP client. By typing the meter IP address in the address field we can view



and download archive files.

Fig.30. View of FTP session called in FileZilla program

11.3.4 Modbus TCP/IP

NR30 meter allows access to internal registers via Ethernet and Modbus TCP/IP. In order to set up a connection it is necessary to set a unique IP address for the meter and to set the connection parameters listed in Table 13.

Table 13

Register	Description	Default value
4146	Device address for Modbus TCP/IP	1

4147	Port number of Modbus TCP	502
4145	Time to close the port of Modbus TCP/IP service [s]	60
4144	The maximum number of simultaneous connections to Modbus TCP/IP service	4

The device address is the device address for Modbus TCP/IP protocol and is not the same as the address value for Modbus RS485 protocol (address in Modbus network register 4100). By setting the "Device Address for Modbus TCP/IP Protocol" parameter to "255", the meter will skip the address analysis in the Modbus protocol frame (broadcast mode).

12 MAP OF REGISTERS OF NR30 METER

In NR30 meter the data is placed in 16- and 32-bit registers. Process variables and parameters of the meter are located in the address space of registers in a manner dependent on the type of the variable. Bits in 16-bit register are numbered from the youngest to the oldest (b0-b15). 32-bit registers contain floating point numbers in IEEE-754 standard. Byte order 3210 – the oldest is sent first.

14

Table

Address range	Value type	Description
4000 – 4159	Integer (16 bits)	Value placed in one 16-bit register. Registers for meter configuration. Description of registers can be found in table 16. Registers for recording and reading.
4200 – 4260	Integer (16 bits)	Value placed in one 16-bit register. Registers for configuration of programmable read-only register group Description of registers can be found in table 15. Registers for recording and reading.
4300 – 4388	Integer (16 bits)	Value placed in one 16-bit register. Registers for configuration of displayed pages, Description of registers can be found in table 19. Registers for recording and reading.
4400- 4485	Integer (16 bits)	Value placed in one 16-bit register. Registers of status, energy values, the meter MAC address, configuration data. Description of registers can be found in table 20. Read-only registers.
6000 – 6970	Float (2x16 bits)	Values placed in two successive 16-bit registers. Registers contain the same data as 32-bit registers of 7500 – 7953 range. Read-only registers. Bytes order (1-0-3-2)
7000 - 7118	Float (2x16 bits)	Content of registers set in registers 4200 – 4359. Bytes order (3-2-1-0)
7200 – 7318	Float (2x16 bits)	Content of registers set in registers 4200 – 4359. Bytes order (1-0-3-2)
7400 - 7459	Float (32 bits)	Content of registers set in registers 4200 – 4359. Values placed in single 32-bit register.
7500 – 7985	Float (32 bits)	Values placed in a single 32-bit register. Description of registers can be found in table 21. Read-only registers.
8000 - 8970	Float (2x16 bits)	Values placed in two successive 16-bit registers. Registers contain the same data as 32-bit registers of 7500 – 7953 range. Read-only registers. Bytes order (3-2-1-0)
9000 – 9144	Float (2x16 bits)	Value is set in the two following 16-bit registers Description of registers is shown in Table 22. Readout registers. Bytes sequence (1-0-3-2)
9200 – 9344	Float (2x16 bits)	Value is set in the two following 16-bit registers. Description of registers is shown in Table 22. Readout registers. Bytes sequence (3-2-1-0)

Table 15

Register address	Operations	Range	Description	Default
4000	RW	0...9999	Protection – password Connections layout 0 - 3Ph/4W 1 - 3Ph/3W 2 - 1Ph/2W	0
4001	RW	0 .. 1	Voltage at terminal 2: 0 - voltage of the first phase L1 1 - voltage of the second phase L2 2 - voltage of the third phase L3	0
4002	RW	0 .. 2	Voltage at terminal 5: 0 - voltage of the first phase L1 1 - voltage of the second phase L2 2 - voltage of the third phase L3	0
4003	RW	0 .. 2	Voltage at terminal 8: 0 - voltage of the first phase L1 1 - voltage of the second phase L2 2 - voltage of the third phase L3	1
4004	RW	0 .. 2	Current at terminals 1,3: 0 - current of the first phase I_{L1} 1 - reversed current direction of phase L1: $-I_{L1}$ 2 - current of the second phase I_{L2} 3 - reversed current direction of phase L2: $-I_{L2}$ 4 - current of the third phase I_{L3} 5 - reversed current direction of phase L3: $-I_{L3}$	0
4005	RW	0..5	Current at terminals 4,6: 0 - current of the first phase I_{L1} 1 - reversed current direction of phase L1: $-I_{L1}$ 2 - current of the second phase I_{L2} 3 - reversed current direction of phase L2: $-I_{L2}$ 4 - current of the third phase I_{L3} 5 - reversed current direction of phase L3: $-I_{L3}$	2
4006	RW	0..5	Current at terminals 7,9: 0 - current of the first phase I_{L1} 1 - reversed current direction of phase L1: $-I_{L1}$ 2 - current of the second phase I_{L2} 3 - reversed current direction of phase L2: $-I_{L2}$ 4 - current of the third phase I_{L3} 5 - reversed current direction of phase L3: $-I_{L3}$	4
4007	RW	0..5	Current input range: 1A or 5 A: 0 - 1 A, 1 - 5 A or 63 A depending on the version	1
4008	RW	0,1	Primary voltage of transformer, two older bytes	0
4009	RW		Reserved	
4010	RW	0..18	Primary voltage of transformer, two younger bytes	100
4011	RW	0..65535	Secondary voltage of transformer x 10	1000
4012	RW	1 .. 10000	Primary current of transformer	5
4013	RW	1 .. 20000	Secondary current of transformer	5
4014	RW	1 .. 1000	Active power averaging time P Demand, apparent power S Demand, current I Demand 0 – 15, 1- 30, 2- 60 minutes	0
4015	RW	0...2	Synchronization with real time clock 0 - no synchronization 1 - synchronization with the clock	1
4016	RW	0.1	Phase input voltage x10	577 or 2300
4017	RW		Reserved	
4018	RW	577 .. 1000 V or 2300 .. 4000 V		

4019	RW	1000 .. 1700 V or 4000 .. 6900 V	Phase-to-phase input voltage x10	1000 or 4000
4020	RW		Reserved	
4021	RW		Reserved	
4022	RW		Reserved	
4023	RW		Reserved	
4024	RW	0...4	Resetting energy meters: 0 – no changes, 1- reset active energies, 2 – erase reactive energies, 3 – erase apparent energies, 4 – erase all energies	0
4025	RW	0.1	Resetting averaged parameters P Demand, S Demand, I Demand	0
4026	RW	0.1	Resetting min, max	0
4027	RW	0.1	Resetting alarm signaling maintenance	0
4028	RW		Reserved	
4029	RW		Reserved	
4030	RW	0...4	Alarm output 1- logic actions of conditions 1, 2, 3 0 – C1 1 – C1 v C2 v C3 2 – C1 ^ C2 ^ C3 3 – (C1 ^ C2) v C3 4 – (C1 v C2 ^ C3)	0
4031	RW	0,1	Alarm output 1- state of relay at alarm occurrence: 0 - relay off 1 - relay on	1
4032	RW	0,1	Alarm output 1- lock of alarm deactivation	0
4033	RW	0,1	Alarm output 1 - signaling of alarm occurrence	0
4034	RW	0.1..52	Alarm output 1 – quantity for condition 1 (c1) (code acc. to table 8)	38
4035	RW	0..9	Alarm output 1 – type for condition 1: 0 – n_on, 1 – noFF, 2 – on, 3 – oFF, 4 – H_on, 5 – HoFF, 6 – 3non, 7 – 3noF, 8 – 3_on, 9 – 3_oF	0
4036	RW	-1440..0..1440 [°oo]	Alarm output 1 - lower value of switching condition 1 of input nominal range	900
4037	RW	-1440..0..1440 [°oo]	Alarm output 1 - upper value of switching condition 1 of input nominal range	1100
4038	RW	0..3600 s	Alarm output 1 – delay of condition 1 activation	0
4039	RW	0..3600 s	Alarm output 1 – delay of condition 1 deactivation	0
4040	RW	0..3600 s	Alarm output 1 – lock of condition 1 reactivation	0
4041	RW	0,1	Alarm output 1 – signaling condition 1 occurrence	0
4042	RW		Reserved	
4043	RW	0.1..52	Alarm output 1 – quantity for condition 2 (c2) (code acc. to table 8)	38
4044	RW	0..9	Alarm output 1 – type for condition 2: 0 – n_on, 1 – noFF, 2 – on, 3 – oFF, 4 – H_on, 5 – HoFF, 6 – 3non, 7 – 3noF, 8 – 3_on, 9 – 3_oF	0
4045	RW	-1440..0..1440 [°oo]	Alarm output 1 - lower value of switching condition 2 of input nominal range	900
4046	RW	-1440..0..1440 [°oo]	Alarm output 1 - upper value of switching condition 2 of input nominal range	1100
4047	RW	0..3600 s	Alarm output 1 – delay of condition 2 activation	0
4048	RW	0..3600 s	Alarm output 1 – delay of condition 2 deactivation	0
4049	RW	0..3600 s	Alarm output 1 – lock of condition 2 reactivation	0
4050	RW	0,1	Alarm output 1 – signaling condition 2 occurrence	0
4051	RW		Reserved	
4052	RW	0.1..52	Alarm output 1 – quantity for condition 3 (c3) (code acc. to table 8)	38
4053	RW	0..9	Alarm output 1 – type for condition 3: 0 – n_on, 1 – noFF, 2 –	0

			on, 3 – oFF, 4 – H_on, 5 – HoFF, 6 – 3non, 7 – 3noF, 8 – 3_on, 9 – 3_oF	
4054	RW	-1440..0..1440 [%oo]	Alarm output 1 - lower value of switching condition 3 of input nominal range	900
4055	RW	-1440..0..1440 [%oo]	Alarm output 1 - upper value of switching condition 3 of input nominal range	1100
4056	RW	0..3600 s	Alarm output 1 – delay of condition 3 activation	0
4057	RW	0..3600 s	Alarm output 1 – delay of condition 3 deactivation	0
4058	RW	0..3600 s	Alarm output 1 – lock of condition 2 reactivation	0
4059	RW	0,1	Alarm output 1 – signaling condition 2 occurrence	0
4060	RW		Reserved	
4061	RW	0...4	Alarm output 2- logic actions of conditions 1, 2, 3 0 – C1 1 – C1 v C2 v C3 2 – C1 \wedge C2 \wedge C3 3 – (C1 \wedge C2) v C3 4 – (C1 v C2 \wedge C3)	0
4062	RW	0,1	Alarm output 2- state of relay at alarm occurrence: 0 - relay off 1 - relay on	1
4063	RW	0,1	Alarm output 2- lock of alarm deactivation	0
4064	RW	0,1	Alarm output 2 - signaling of alarm occurrence	0
4065	RW	0.1..52	Alarm output 2 – quantity for condition 1 (c1) (code acc. to table 8)	38
4066	RW	0..9	Alarm output 2 – type for condition 1: 0 – n_on, 1 – noFF, 2 – on, 3 – oFF, 4 – H_on, 5 – HoFF, 6 – 3non, 7 – 3noF, 8 – 3_on, 9 – 3_oF	0
4067	RW	-1440..0..1440 [%oo]	Alarm output 2 - lower value of switching condition 1 of input nominal range	900
4068	RW	-1440..0..1440 [%oo]	Alarm output 2 - upper value of switching condition 1 of input nominal range	1100
4069	RW	0..3600 s	Alarm output 2 – delay of condition 1 activation	0
4070	RW	0..3600 s	Alarm output 2 – delay of condition 1 deactivation	0
4071	RW	0..3600 s	Alarm output 2 – lock of condition 1 reactivation	0
4072	RW	0,1	Alarm output 2– signaling condition 1 occurrence	0
4073	RW		Reserved	
4074	RW	0.1..52	Alarm output 2 – quantity for condition 2 (c2) (code acc. to table 8)	38
4075	RW	0..9	Alarm output 2 – type for condition 2: 0 – n_on, 1 – noFF, 2 – on, 3 – oFF, 4 – H_on, 5 – HoFF, 6 – 3non, 7 – 3noF, 8 – 3_on, 9 – 3_oF	0
4076	RW	-1440..0..1440 [%oo]	Alarm output 2 - lower value of switching condition 2 of input nominal range	900
4077	RW	-1440..0..1440 [%oo]	Alarm output 2 - upper value of switching condition 2 of input nominal range	1100
4078	RW	0..3600 s	Alarm output 2 – delay of condition 2 activation	0
4079	RW	0..3600 s	Alarm output 2 – delay of condition 2 deactivation	0
4080	RW	0..3600 s	Alarm output 2 – lock of condition 2 reactivation	0
4081	RW	0,1	Alarm output 2– signaling condition 2 occurrence	0
4082	RW		Reserved	
4083	RW	0.1..52	Alarm output 2 – quantity for condition 3 (c3) (code acc. to table 8)	38
4084	RW	0..9	Alarm output 2 – type for condition 3: 0 – n_on, 1 – noFF, 2 – on, 3 – oFF, 4 – H_on, 5 – HoFF, 6 – 3non, 7 – 3noF, 8 – 3_on, 9 – 3_oF	0
4085	RW	-1440..0..1440 [%oo]	Alarm output 2 - lower value of switching condition 3 of input nominal range	900
4086	RW	-1440..0..1440 [%oo]	Alarm output 2 - upper value of switching condition 3 of input nominal range	1100

4087	RW	0..3600 s	Alarm output 2 – delay of condition 3 activation	0
4088	RW	0..3600 s	Alarm output 2 – delay of condition 3 deactivation	0
4089	RW	0..3600 s	Alarm output 2 – lock of condition 2 reactivation	0
4090	RW	0,1	Alarm output 2 – signaling condition 2 occurrence	0
4091	RW		Reserved	
4092	RW		Reserved	
4093	RW		Reserved	
4094	RW		Reserved	
4095	RW		Reserved	
4096	RW		Reserved	
4097	RW		Reserved	
4098	RW		Reserved	
4099	RW		Reserved	
4100	RW	1..247	Address on the Modbus network.	1
4101	RW	0..3	Transmission mode: 0->8n2, 1->8e1, 2->8o1, 3->8n1	0
4102	RW	0..5	Baud rate: 0->4800, 1->9600 2->19200, 3->38400, 4->57600, 5->115200	1
4103	RW		Reserved	
4104	RW	0.1	Update the change of transmission parameters	0
4105	RW		Reserved	
4106	RW	0...0xFFFF	Group 1, archived values bit0 – reserved, bit1- U1, bit2- I1, ... ,bit15- PF2 ,acc. to table 8	0x0000
4107	RW	0...0xFFFF	Group 1, archived values bit16- tg2, bit17-THD U2, ... ,bit31- ΣQ ,acc to table 8	0x0000
4108	RW	0...0xFFFF	Group 1, archived values bit32- ΣS, bit33- PF avg, ... ,bit47- En P- ,acc. to table 8	0x0000
4109	RW	0...0x000F	Group 1, archived values bit48 En Q ind,...,bit51-Phase order acc. to table 8	0x0000
4110	RW	1...52	Group 1, value triggering archiving	1
4111	RW	0..9	Group 1, archiving type : 0 – n_on, 1 – noFF, 2 – on, 3 – oFF, 4 – H_on, 5 – HoFF, 6 – 3non, 7 – 3noF, 8 – 3_on, 9 – 3_oF	0
4112	RW	-1440..0..1440	Group 1, lower threshold of archiving in %oo	900
4113	RW	-1440..0..1440	Group 1, upper threshold of archiving in %oo	1100
4114	RW	1 .. 3600	Group 1, archiving period in seconds	1
4115	RW	0...0xFFFF	Group 2, archived values bit0 – reserved, bit1- U1, bit2- I1, ... ,bit15- PF2 ,acc. to table 8	0x0000
4116	RW	0...0xFFFF	Group 2, archived values bit16- tg2, bit17-THD U2, ... ,bit31- ΣQ ,acc to table 8	0x0000
4117	RW	0...0xFFFF	Group 2, archived values bit32- ΣS, bit33- PF avg, ... ,bit47- En P- ,acc. to table 8	0x0000
4118	RW	0...0x000F	Group 2, archived values bit48 En Q ind,...,bit51-Phase order acc. to table 8	0x0000
4119	RW	1...52	Group 2, value triggering archiving	1
4120	RW	0..9	Group 2, archiving type : 0 – n_on, 1 – noFF, 2 – on, 3 – oFF, 4 – H_on, 5 – HoFF, 6 – 3non, 7 – 3noF, 8 – 3_on, 9 – 3_oF	0
4121	RW	-1440..0..1440	Group 2, lower threshold of archiving in %oo	900
4122	RW	-1440..0..1440	Group 2, upper threshold of archiving in %oo	1100
4123	RW	1 .. 3600	Group 2, archiving period in seconds	1
4124	RW		Reserved	
4125	RW	0,1	Copying the archive to the file archive memory. „1 „– copy the archive to file archive memory /only records which have been recorded since the last copying/	0
4126	RW	0,1	Deleting the whole internal archive	0
4127	RW	0 .. 2	Field separator: 0 - comma, 1- semicolon; 2 - tab ''	,
4128	RW	0,1	Decimal separator 0 - dot '.' 1 - comma ','	.
4129	RW		Reserved	

4130	RW	0,1	Enabling/disabling DHCP client (the service of automatic acquiring the parameters of Ethernet interface IP protocol of the meter from external DHCP servers located within the same LAN network). 0 - DHCP service disabled – manually configure the IP address and subnet mask of the meter; 1- DHCP service enabled, after powering up, or after selecting the menu option APPL, or after entering value “1” to register 4099 the meter will automatically receive the IP address, subnet mask and gateway address from the DHCP server, the gateway address will be the address of the server which assigned the parameters to the meter,	1
4131	RW	0...65535	Third and second byte (B3.B2) of meter IP address, format IPv4 : B3.B2.B1.B0	49320 (0xC0A8 = 192.168)
4132	RW	0...65535	First and zero byte (B1.B0) of meter IP address, format IPv4: B3.B2.B1.B0	356 (0x0164 = 1.100)
4133	RW	0...65535	Third and second byte (B3.B2) of meter subnet mask address, mask format: B3.B2.B1.B0	65535
4134	RW	0...65535	First and zero byte (B1.B0) of meter subnet mask address, mask format: B3.B2.B1.B0	65280
4135	RW	0...65535	Third and second byte (B3.B2) of meter default gateway, gateway address format: B3.B2.B1.B0	49320
4136	RW	0...65535	First and zero byte (B1.B0) of meter default gateway address, gate address format: B3.B2.B1.B0	257
4137	RW	0...65535	Third and second byte (B3.B2) of meter DNS address, format IPv4: B3.B2.B1.B0	0x0808=8.8
4138	RW	0...65535	First and zero byte (B1.B0) of meter DNS address, format IPv4: B3.B2.B1.B0	0x0808=8.8
4139	RW		Reserved	
4140	RW		Reserved	
4141	RW	0 .. 2	Ethernet interface baud rate: 0 – automatic selection of baud rate 1 – 10 Mb/s 2 – 100 Mb/s	0
4142	RW	20...65535	Commend port number of FTP server	21
4143	RW	20...65535	Data port number of FTP server	1025
4144	RW	1...4	The maximum number of simultaneous connections to Modbus TCP/IP service	1
4145	RW	10...600	Time to close the port of Modbus TCP/IP service, in seconds	60
4146	RW	0...255	Device address for Modbus TCP/IP	1
4147	RW	0...65535	Port number of Modbus TCP	502
4148	RW	80...65535	Web server port number	80
4149	RW	0,1	Memorizing new parameters of Ethernet interface and re-initiating the interface 0 – no changes, 1 – memorizing new parameters and re-initiating Ethernet interface,	0
4150	RW	0..2	Menu language: 0-ENG, 1-PL, 2-DE	1
4151	RW	0,1	Reserved	0
4152	RW	0.1	Recording standard parameters (with reset of energies and min and max averaged parameters), including Ethernet,	0
4153	RW	0..59	Seconds	0
4154	RW	0...2359	Hour *100 + Minutes	0
4155	RW	101...1231	Month * 100 + day	101
4156	RW	2015...2077	Year	2015
4157	RW		Reserved	
4158	RW		Reserved	
4159	RW		Reserved	

The values of alarm conditions switching recorded in registers 4036, 4037, 4054, 4055, 4067, 4068, 4076, 4077, 4085, 4086 are multiplied by 10 e.g. the value of 100 % should be typed as “1000”.

Table 16

Register address	Operations	Range	Description	Default
4255	RW	7500 .. 7957	Register 56 of programmable read-only register group	7559
4256	RW	7500 .. 7957	Register 57 of programmable read-only register group	7560
4257	RW	7500 .. 7957	Register 58 of programmable read-only register group	7561
4258	RW	7500 .. 7957	Register 59 of programmable read-only register group	7566
4259	RW	7500 .. 7957	Register 60 of programmable read-only register group	7567
4260	RW	0,1	Restore factory group 0 – no changes, 1 – restore the factory group	0

Table 18

Address of 16-bit registers 2x16 1032/ 2x16 3210	Register address 32 bits	Operations	Description
7200/7000	7400	R	Content of register set in register 4200
7202/7002	7401	R	Content of register set in register 4201
7204/7004	7402	R	Content of register set in register 4202
7206/7006	7403	R	Content of register set in register 4203
7208/7008	7404	R	Content of register set in register 4204
7210/7010	7405	R	Content of register set in register 4205
7212/7012	7406	R	Content of register set in register 4206
7214/7014	7407	R	Content of register set in register 4207
7216/7016	7408	R	Content of register set in register 4208
7218/7018	7409	R	Content of register set in register 4209
7220/7020	7410	R	Content of register set in register 4210
7222/7022	7411	R	Content of register set in register 4211
7224/7024	7412	R	Content of register set in register 4212
7226/7026	7413	R	Content of register set in register 4213
7228/7028	7414	R	Content of register set in register 4214
7230/7030	7415	R	Content of register set in register 4215
7232/7032	7416	R	Content of register set in register 4216
7234/7034	7417	R	Content of register set in register 4217
7236/7036	7418	R	Content of register set in register 4218
7238/7038	7419	R	Content of register set in register 4219
7240/7040	7420	R	Content of register set in register 4220
7242/7042	7421	R	Content of register set in register 4221
7244/7044	7422	R	Content of register set in register 4222
7246/7046	7423	R	Content of register set in register 4223
7248/7048	7424	R	Content of register set in register 4224
7250/7050	7425	R	Content of register set in register 4225
7252/7052	7426	R	Content of register set in register 4226
7254/7054	7427	R	Content of register set in register 4227
7256/7056	7428	R	Content of register set in register 4228
7258/7058	7429	R	Content of register set in register 4229
7260/7060	7430	R	Content of register set in register 4230
7262/7062	7431	R	Content of register set in register 4231
7264/7064	7432	R	Content of register set in register 4232
7266/7066	7433	R	Content of register set in register 4233
7268/7068	7434	R	Content of register set in register 4234
7270/7070	7435	R	Content of register set in register 4235
7272/7072	7436	R	Content of register set in register 4236
7274/7074	7437	R	Content of register set in register 4237
7276/7076	7438	R	Content of register set in register 4238
7278/7078	7439	R	Content of register set in register 4239
7280/7080	7440	R	Content of register set in register 4240
7282/7082	7441	R	Content of register set in register 4241
7284/7084	7442	R	Content of register set in register 4242
7286/7086	7443	R	Content of register set in register 4243

7288/7088	7444	R	Content of register set in register 4244
7290/7090	7445	R	Content of register set in register 4245
7292/7092	7446	R	Content of register set in register 4246
7294/7094	7447	R	Content of register set in register 4247
7296/7096	7448	R	Content of register set in register 4248
7298/7098	7449	R	Content of register set in register 4249
7300/7100	7450	R	Content of register set in register 4250
7302/7102	7451	R	Content of register set in register 4251
7304/7104	7452	R	Content of register set in register 4252
7306/7106	7453	R	Content of register set in register 4253
7308/7108	7454	R	Content of register set in register 4254
7310/7110	7455	R	Content of register set in register 4255
7312/7112	7456	R	Content of register set in register 4256
7314/7114	7457	R	Content of register set in register 4257
7316/7116	7458	R	Content of register set in register 4258
7318/7118	7459	R	Content of register set in register 4259

Table 19

Register address	Operations	Range	Description	Default
4300	RW	0...1	Backlight: 0 – disabled, 1 – enabled	1
4301	RW	0 .. 3600	Backlight shutdown time	0
4302	RW		Reserved	
4303	RW	0x0001...0xFFFF	Enabling displaying pages Bit0 – page 1, Bit1 – page 2, ...Bit15 – page 16	0xFFFF
4304	RW	0x0000...0x007F	Enabling displaying pages Bit0 – page 17, Bit1 – page 18, ...Bit6 – page 23	0x007F
4305	RW	00..50	Page 1 display 1, U1	1
4306	RW	00..50	Page 1 display 2, U2	10
4307	RW	00..50	Page 1 display 3, U3	19
4308	RW	00..50	Page 2 display 1, U12	38
4309	RW	00..50	Page 2 display 2, U23	39
4310	RW	00..50	Page 2 display 3, U31	40
4311	RW	00..50	Page 3 display 1, I1	2
4312	RW	00..50	Page 3 display 2, I2	11
4313	RW	00..50	Page 3 display 3, I3	20
4314	RW	00..50	Page 4 display 1, P1	3
4315	RW	00..50	Page 4 display 2, P2	12
4316	RW	00..50	Page 4 display 3, P3	21
4317	RW	00..50	Page 5 display 1, Q1	4
4318	RW	00..50	Page 5 display 2, Q2	13
4319	RW	00..50	Page 5 display 3, Q3	22
4320	RW	00..50	Page 6 display 1, PF1	6
4321	RW	00..50	Page 6 display 2, PF2	15
4322	RW	00..50	Page 6 display 3, PF3	24
4323	RW	00..50	Page 7 display 1, tg1	7
4324	RW	00..50	Page 7 display 2, tg2	16
4325	RW	00..50	Page 7 display 3, tg3	25
4326	RW	00..50	Page 8 display 1, ΣP	30
4327	RW	00..50	Page 8 display 2, ΣQ	31
4328	RW	00..50	Page 8 display 3, ΣS	32
4329	RW	00..50	Page 9 display 1, U avg	28
4330	RW	00..50	Page 9 display 2, I avg	29
4331	RW	00..50	Page 9 display 3, I(N)	45
4332	RW	00..50	Page 10 display 1, PFavg	33
4333	RW	00..50	Page 10 display 2, tgavg	34

Register address	Operations	Range	Description	Default
4334	RW	00..50	Page 10 display 3, f	37
4335	RW	00..50	Page 11 display 1, U1	1
4336	RW	00..50	Page 11 display 2, I1	2
4337	RW	00..50	Page 11 display 3, P1	3
4338	RW	00..50	Page 12 display 1, Q1	4
4339	RW	00..50	Page 12 display 2, S1	5
4340	RW	00..50	Page 12 display 3, PF1	6
4341	RW	00..50	Page 13 display 1, U2	10
4342	RW	00..50	Page 13 display 2, I2	11
4343	RW	00..50	Page 13 display 3, P2	12
4344	RW	00..50	Page 14 display 1, Q2	13
4345	RW	00..50	Page 14 display 2, S2	14
4346	RW	00..50	Page 14 display 3, PF2	15
4347	RW	00..50	Page 15 display 1, U3	19
4348	RW	00..50	Page 15 display 2, I3	20
4349	RW	00..50	Page 15 display 3, P3	21
4350	RW	00..50	Page 16 display 1, Q3	22
4351	RW	00..50	Page 16 display 2, S3	23
4352	RW	00..50	Page 16 display 3, PF3	24
4353	RW	00..50	Page 17 display 1, P DMD	42
4354	RW	00..50	Page 17 display 2, S DMD	43
4355	RW	00..50	Page 17 display 3, I DMD	44
4356	RW	00..50	Page 18 display 1, ΣP	30
4357	RW	00..50	Page 18 display 2, En P+	48
4358	RW	00..50	Page 18 display 3, En P-	49
4359	RW	00..50	Page 19 display 1, ΣQ	31
4360	RW	00..50	Page 19 display 2, EnQL	50
4361	RW	00..50	Page 19 display 3, EnQC	51
4362	RW	00..50	Page 20 display 1, ΣS	32
4363	RW	00..50	Page 20 display 2, En S	52
4364	RW	00..50	Page 20 display 3, f	37
4365	RW	00..50	Page 21 display 1, TH U1	8
4366	RW	00..50	Page 21 display 2, TH U2	17
4367	RW	00..50	Page 21 display 3, TH U3	26
4368	RW	00..50	Page 22 display 1, TH I1	9
4369	RW	00..50	Page 22 display 2, TH I2	18
4370	RW	00..50	Page 22 display 3, TH I3	17
4371	RW		Reserved	
4372	RW		Reserved	
4373	RW		Reserved	
4374	RW		Reserved	
4375	RW		Reserved	
4376	RW		Reserved	
4377	RW		Reserved	
4378	RW		Reserved	
4379	RW		Reserved	
4380	RW		Reserved	
4381	RW		Reserved	
4382	RW		Reserved	
4383	RW		Reserved	
4384	RW		Reserved	
4385	RW	0..3	Restore factory pages 0 - no 1 - 3Ph/4W 2 - 3Ph/3W 3 - 1PH/2W	0

Register address	Operations	Range	Description	Default
4386	RW		Reserved	
4387	RW		Reserved	
4388	RW		Reserved	

Table 20

Register address	Operations	Range	Description	Default
4400	R		Reserved	
4401	R	0..65535	Identifier	E6
4402	R	0..65535	Bootloader version x 100	-
4403	R	0..65535	Program version x100	-
4404	R		Reserved	
4405	R	0..65535	Ordering code	-
4406	R	0..65535	Nominal voltage x10	577/2300
4407	R	0..65535	Nominal voltage x10	1000/4000
4408	R	0..65535	Nominal current x 100	100/6300
4409	R	0..65535	Nominal current x 100	500/6300
4410	R		Reserved	
4411	R	0..65535	Seventh and sixth byte (B7.B6) of serial number , format B7:B6:B5:B4:B3:B2:B1:B0	-
4412	R	0..65535	Fifth and fourth byte (B5.B4) of serial number , format B7:B6:B5:B4:B3:B2:B1:B0	-
4413	R	0..65535	Third and second byte (B3.B2) of serial number , format B7:B6:B5:B4:B3:B2:B1:B0	-
4414	R	0..65535	First and zero byte (B1.B0) of serial number , format B7:B6:B5:B4:B3:B2:B1:B0	-
4415	R	0..65535	Status register 1– description below	0
4416	R	0..65535	Status register 2– description below	0
4417	R	0..65535	Status register 3– description below	0
4418	R	0..65535	Status register 4– description below	0
4419	R	0..65535	Status register 5– description below	0
4420	R	0..65535	Status register 6– description below	0
4421	R	0...65535	Fifth and fourth byte (B5.B4) of meter MAC address, format B5:B4:B3:B2:B1:B0	-
4422	R	0...65535	Third and second byte (B3.B2) of meter MAC address, format B5:B4:B3:B2:B1:B0	-
4423	R	0...65535	First and zero byte (B1.B0) of meter MAC address, format B5:B4:B3:B2:B1:B0	-
4424	R	0...65535	Status register 7– description below	0
4425	R		Reserved	0
4426	R	0..152	Active imported energy, two older bytes	0
4427	R	0..65535	Active imported energy, two younger bytes	0
4428	R	0..152	Active exported energy, two older bytes	0
4429	R	0..65535	Active exported energy, two younger bytes	0
4430	R	0..152	Reactive inductive energy, two older bytes	0
4431	R	0..65535	Reactive inductive energy, two younger bytes	0
4432	R	0..152	Reactive capacitive energy, two older bytes	0
4433	R	0..65535	Reactive capacitive energy, two younger bytes	0
4434	R	0..152	Apparent energy, two older bytes	0
4435	R	0..65535	Apparent energy, two younger bytes	0
4436	R		Reserved	
4437	R		Reserved	
4438	R		Reserved	
4439	R		Reserved	
4440	R	0..1000	File archive usage in %	0
4441	R	0..1000	Group 1 archive internal memory usage in %	0
4442	R	0..1000	Group 2 archive internal memory usage in %	0

4443	R	0..1000	Total usage of the archive internal memory for group 1 and 2 in % _{oo}	0
4444	R	0..1000	Percentage progress in copying the internal archive to the file archive for group 1 in % _{oo}	0
4445	R	0..1000	Percentage progress in copying the internal archive to the file archive for group 2 in % _{oo}	0
4446	R	0..1000	Percentage progress in copying the internal archive to the file archive for group 1 and 2 in % _{oo}	0
4447	R		reserved	0
...				
4461	R		reserved	0
4462	R	0..152	Active imported 3-phase energy for the previous year, two older bytes	0
4463	R	0..65535	Active imported 3-phase energy for the previous year, two younger bytes	0
4464	R	0..152	Active exported 3-phase energy for the previous year, two older bytes	0
4465	R	0..65535	Active exported 3-phase energy for the previous year, two younger bytes	0
4466	R	0..152	Active imported 3-phase energy for the current year, two older bytes	0
4467	R	0..65535	Active imported 3-phase energy for the current year, two younger bytes	0
4468	R	0..152	Active exported 3-phase energy for the current year, two older bytes	0
4469	R	0..65535	Active exported 3-phase energy for the current year, two younger bytes	0
4470	R	0..152	Active imported 3-phase energy for the current month, two older bytes	0
4471	R	0..65535	Active imported 3-phase energy for the current month, two younger bytes	0
4472	R	0..152	Active exported 3-phase energy for the current month, two older bytes	0
4473	R	0..65535	Active exported 3-phase energy for the current month, two younger bytes	0
4474	R	0..152	Active imported 3-phase energy for the current week, two older bytes	0
4475	R	0..65535	Active imported 3-phase energy for the current week, two younger bytes	0
4476	R	0..152	Active exported 3-phase energy for the current week, two older bytes	0
4477	R	0..65535	Active exported 3-phase energy for the current week, two younger bytes	0
4478	R	0..152	Active imported 3-phase energy for the current 48 hours, two older bytes	0
4479	R	0..65535	Active imported 3-phase energy for the current 48 hours, two younger bytes	0
4480	R	0..152	Active exported 3-phase energy for the current 48 hours, two older bytes	0
4481	R	0..65535	Active exported 3-phase energy for the current 48 hours, two younger bytes	0

4482	R	0..152	Active imported 3-phase energy for the current 24 hours, two older bytes	0
4483	R	0..65535	Active imported 3-phase energy for the current 24 hours, two younger bytes	0
4484	R	0..152	Active exported 3-phase energy for the current 24 hours, two older bytes	0
4485	R	0..65535	Active exported 3-phase energy for the current 24 hours, two younger bytes	0

Energy is made available in hundreds of watt-hours (var-hours) in double 16-bit register, and for this reason, they must be divided by 100 when calculating values of particular energy from registers, i.e.:

$$\text{Imported active energy} = (\text{register 4426 value} \times 65536 + \text{register 4427 value}) / 100 \text{ [kWh]}$$

$$\text{Exported active energy} = (\text{register 4428 value} \times 65536 + \text{register 4429 value}) / 100 \text{ [kWh]}$$

$$\text{Reactive inductive energy} = (\text{register 4430 value} \times 65536 + \text{register 4431 value}) / 100 \text{ [kVarh]}$$

$$\text{Reactive capacitive energy} = (\text{register 4432 value} \times 65536 + \text{register 4433 value}) / 100 \text{ [kVarh]}$$

$$\text{Apparent energy} = (\text{register 4434 value} \times 65536 + \text{register 4435 value}) / 100 \text{ [kVAh]}$$

Similarly, energy from registers 4462 to 4485 should be converted.

Device status register 1 (address 4415, R):

Bit 15 – “1” – FRAM memory corruption	Bit 7 – “1” – error of phase sequence
Bit 14 - "1" - no input calibration	Bit 6 – “1” – error in MQTT registries
Bit13 - Reserved	Bit 5 – “1” – error in the supervisory relay registers
Bit 12 – reserved	Bit 4 – reserved
Bit 11 – “1” – error in configuration registers	Bit 3 – reserved
Bit 10 – “1” – error in displayed pages registers	Bit 2 – „1” – presence of Ethernet and internal memory
Bit 9 – “1” – error in configuration registers of programmable read-only register group	Bit 1 – “1” – used battery of RTC
Bit 8 – “1” – error of energy values	Bit 0 – reserved

Status register 2 (address 4416, R):

Bit 15 - “1” – signaling of condition 3 occurrence for alarm 2	Bit 7 - “1” – signaling of condition 3 occurrence for alarm 1
Bit 14 - “1” – signaling of condition 2 occurrence for alarm 2	Bit 6 - “1” – signaling of condition 2 occurrence for alarm 1
Bit 13 - “1” – signaling of condition 1 occurrence for alarm 2	Bit 5 - “1” – signaling of condition 1 occurrence for alarm 1
Bit 12 - “1” – signaling of alarm 2 occurrence	Bit 4 - “1” – signaling of alarm 1 occurrence
Bit 11 - “1” – alarm 2 condition 3 active	Bit 3 - “1” – alarm 1 condition 3 active
Bit 10 - “1” – alarm 2 condition 2 active	Bit 2 - “1” – alarm 1 condition 2 active
Bit 9 - “1” – alarm 2 condition 1 active	Bit 1 - “1” – alarm 1 condition 1 active
Bit 8 - “1” – alarm 2 active	Bit 0 - “1” – alarm 1 active

Status register 3 (address 4417, R): File archive status

Bit 15 – Ethernet connected	Bit 7 – Archiving group 1 enabled
Bit 14 – reserved	Bit 6 – reserved
Bit 13 – reserved	Bit 5 – copying internal memory to file archive from 2nd archiving group
Bit 12 – reserved	Bit 4 – copying internal memory to file archive from 1st archiving group
Bit 11 – "0" – waiting until archiving conditions are met, "1" - archiving in 2-nd archiving group,	Bit 3 – File archive full, (less than 14 days to complete archive filling at 1 sec. interval)
Bit 10 – "0" – waiting until archiving conditions are met, "1" - archiving in 1-st archiving group,	Bit 2 – File archive used in 70%
Bit 9 – reserved	Bit 1 – File archive properly initiated
Bit 8 – Archiving group 2 enabled	Bit 0 – Error of file archive system

Status register 4 (address 4418, R) type of reactive power :

Bit 15 – reserved	Bit 7 – "1" – capacitive L3 minimum
Bit 14 – "1" - Demand- capacity 3L max.	Bit 6 – "1" – capacitive L3
Bit 13 – "1" - Demand- capacity 3L min.	Bit 5 – "1" – capacitive L2 maximum
Bit 12 – "1" - Demand- capacity 3L	Bit 4 – "1" – capacitive L2 minimum
Bit 11 – "1" – capacitive 3L maximum	Bit 3 – "1" – capacitive L2
Bit 10 – "1" – capacitive 3L minimum	Bit 2 – "1" – capacitive L1 maximum
Bit 9 – "1" – capacitive 3L	Bit 1 – "1" – capacitive L1 minimum
Bit 8 – "1" – capacitive L3 maximum	Bit 0 – "1" – capacitive L1

Status register 5 (address 4419, R):

Bit 8 – "1" – alarm 1, condition 3 for L3 phase active
 Bit 7 – "1" – alarm 1, condition 3 for L2 phase active
 Bit 6 – "1" – alarm 1, condition 3 for L1 phase active
 Bit 5 – "1" – alarm 1, condition 2 for L3 phase active
 Bit 4 – "1" – alarm 1, condition 2 for L2 phase active
 Bit 3 – "1" – alarm 1, condition 2 for L1 phase active
 Bit 2 – "1" – alarm 1, condition 1 for L3 phase active
 Bit 1 – "1" – alarm 1, condition 1 for L2 phase active
 Bit 0 – "1" – alarm 1, condition 1 for L1 phase active

Status register 6 (address 4420, R):

Bit 8 – "1" – alarm 2, condition 3 for L3 phase active
 Bit 7 – "1" – alarm 2, condition 3 for L2 phase active
 Bit 6 – "1" – alarm 2, condition 3 for L1 phase active
 Bit 5 – "1" – alarm 2, condition 2 for L3 phase active
 Bit 4 – "1" – alarm 2, condition 2 for L2 phase active
 Bit 3 – "1" – alarm 2, condition 2 for L1 phase active
 Bit 2 – "1" – alarm 2, condition 1 for L3 phase active
 Bit 1 – "1" – alarm 2, condition 1 for L2 phase active
 Bit 0 – "1" – alarm 2, condition 1 for L1 phase active

Status register 7 (address 4424, R)

Bit 8 – reserved
 Bit 7 – reserved
 Bit 6 – reserved
 Bit 5 – reserved
 Bit 4 – reserved
 Bit 3 – reserved
 Bit 2 – reserved
 Bit 1 – "1" – functions of MQTT protocol enabled
 Bit 0 – "1" – functions of supervisory relay enabled

Table 21

Address of 16-bit registers 2x16 1032/ 2x16 3210	Register address 32 bits	Operation s	Description	Unit	3Ph / 4W	3Ph / 3W	1Ph / 2W
6000/8000	7500	R	Voltage of L1 phase	V	✓	x	✓
6002/8002	7501	R	Current of L1 phase	A	✓	✓	✓
6004/8004	7502	R	Active power of L1 phase	W	✓	x	✓
6006/8006	7503	R	Reactive power of L1 phase	VAr	✓	x	✓
6008/8008	7504	R	Apparent power of L1 phase	VA	✓	x	✓
6010/8010	7505	R	Factor of active power of L1 phase (PF1=P1/S1)	-	✓	x	✓
6012/8012	7506	R	tgφ factor of L1 phase (tg1=Q1/P1)	-	✓	x	✓
6014/8014	7507	R	THD U1*	%	✓	✓	✓
6016/8016	7508	R	THD I1	%	✓	✓	✓
6018/8018	7509	R	Voltage of L2 phase	V	✓	x	x
6020/8020	7510	R	Current of L2 phase	A	✓	✓	x
6022/8022	7511	R	Active power of L2 phase	W	✓	x	x
6024/8024	7512	R	Reactive power of L2 phase	VAr	✓	x	x
6026/8026	7513	R	Apparent power of L2 phase	VA	✓	x	x
6028/8028	7514	R	Factor of active power of L2 phase (PF2=P2/S2)	-	✓	x	x
6030/8030	7515	R	tgφ factor of L2 phase (tg2=Q2/P2)	-	✓	x	x
6032/8032	7516	R	THD U2*	%	✓	✓	x
6034/8034	7517	R	THD I2	%	✓	✓	x
6036/8036	7518	R	Voltage of L3 phase	V	✓	x	x
6038/8038	7519	R	Current of L3 phase	A	✓	✓	x
6040/8040	7520	R	Active power of L3 phase	W	✓	x	x
6042/8042	7521	R	Reactive power of L3 phase	VAr	✓	x	x
6044/8044	7522	R	Apparent power of L3 phase	VA	✓	x	x
6046/8046	7523	R	Factor of active power of L3 phase (PF3=P3/S3)	-	✓	x	x
6048/8048	7524	R	tgφ factor of L3 phase (tg3=Q3/P3)	-	✓	x	x
6050/8050	7525	R	THD U3*	%	✓	✓	x
6052/8052	7526	R	THD I3	%	✓	✓	x
6054/8054	7527	R	Average 3-phase voltage	V	✓	x	x
6056/8056	7528	R	Average 3-phase current	A	✓	✓	x
6058/8058	7529	R	3-phase active power (P1+P2+P3)	W	✓	✓	x
6060/8060	7530	R	3-phase reactive power (Q1+Q2+Q3)	VAr	✓	✓	x
6062/8062	7531	R	3-phase apparent power (S1+S2+S3)	VA	✓	✓	x
6064/8064	7532	R	3-phase active power factor (PF=P/S)	-	✓	✓	x
6066/8066	7533	R	tgφ factor 3-phase average (tg=Q/P)	-	✓	✓	x
6068/8068	7534	R	THD U* 3-phase average	%	✓	✓	x
6070/8070	7535	R	THD I 3-phase average	%	✓	✓	x
6072/8072	7536	R	Frequency	f	✓	✓	✓
6074/8074	7537	R	Phase-to-phase voltage L ₁₋₂	V	✓	✓	x
6076/8076	7538	R	Phase-to-phase voltage L ₂₋₃	V	✓	✓	x
6078/8078	7539	R	Phase-to-phase voltage L ₃₋₁	V	✓	✓	x
6080/8080	7540	R	Average phase-to-phase voltage L1-2	V	✓	✓	x
6082/8082	7541	R	averaged active power (P Demand)	W	✓	✓	x
6084/8084	7542	R	averaged apparent power (S Demand)	VA	✓	✓	x
6086/8086	7543	R	averaged current (I Demand)	A	✓	✓	x
6088/8088	7544	R	Current in neutral wire (calculated from vectors)	A	✓	x	x
6090/8090	7545	R	3-phase active imported energy (number of register 7546 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6092/8092	7546	R	3-phase active imported energy (counter up to 99999.99 kWh)	kWh	✓	✓	✓
6094/8094	7547	R	3-phase active exported energy (number of register 7548 overflows, reset after 9999.9 MWh is	100 MWh	✓	✓	✓

			reached)				
6096/8096	7548	R	3 -phase active exported energy (counter up to 99999.99 kWh)	kWh	✓	✓	✓
6098/8098	7549	R	3-phase reactive inductive energy (number of register 7550 overflows, reset after 9999.9 MVArh is reached)	100 MVArh	✓	✓	✓
6100/8100	7550	R	Reactive inductive energy 3 -phase (counter up to 99999.99 kVArh)	kVArh	✓	✓	✓
6102/8102	7551	R	3-phase reactive capacitive energy (number of register 7552 overflows, reset after 9999.9 MVArh is reached)	100 MVArh	✓	✓	✓
6104/8104	7552	R	Reactive capacitive energy 3 -phase (counter up to 99999.99 kVArh)	kVArh	✓	✓	✓
6106/8106	7553	R	Apparent energy (number of register 7554 overflows, reset after 9999.9 MVAh is reached)	100 MVAh	✓	✓	✓
6108/8108	7554	R	Apparent energy (counter up to 99999.99 kVAh)	kVAh	✓	✓	✓
6110/8110	7555	R	Time – seconds	sec	✓	✓	✓
6112/8112	7556	R	Time – hours, minutes		✓	✓	✓
6114/8114	7557	R	Date - month, day		✓	✓	✓
6116/8116	7558	R	Year – 2014 - 2100		✓	✓	✓
6118/8118	7559	R	Status register 1	-	✓	✓	✓
6120/8120	7560	R	Status register 2	-	✓	✓	✓
6122/8122	7561	R	Status register 3	-	✓	✓	✓
6124/8124	7562	R	Status register 4	-	✓	✓	✓
6126/8126	7563	R	Status register 5	-	✓	✓	✓
6128/8128	7564	R	Status register 6	-	✓	✓	✓
6130/7130	7565	R	Reserved	-	-	-	-
6132/8132	7566	R	Reserved	-	-	-	-
6134/8134	7567	R	Reserved	-	-	-	-
6136/8136	7568	R	Voltage L1 min	V	✓	x	✓
6138/8138	7569	R	Voltage L1 max	V	✓	x	✓
6140/8140	7570	R	Voltage L2 min	V	✓	x	x
6142/8142	7571	R	Voltage L2 max	V	✓	x	x
6144/8144	7572	R	Voltage L3 min	V	✓	x	x
6146/8146	7573	R	Voltage L3 max	V	✓	x	x
6148/8148	7574	R	Current L1 min	A	✓	✓	x
6150/8150	7575	R	Current L1 max	A	✓	✓	x
6152/8152	7576	R	Current L2 min	A	✓	✓	x
6154/8154	7577	R	Current L2 max	A	✓	✓	x
6156/8156	7578	R	Current L3 min	A	✓	✓	x
6158/8158	7579	R	Current L3 max	A	✓	✓	x
6160/8160	7580	R	Active power L1 min	W	✓	x	✓
6162/8162	7581	R	Active power L1 max	W	✓	x	✓
6164/8164	7582	R	Active power L2 min	W	✓	x	x
6166/8166	7583	R	Active power L2 max	W	✓	x	x
6168/8168	7584	R	Active power L3 min	W	✓	x	x
6170/8170	7585	R	Active power L3 max	W	✓	x	x
6172/8172	7586	R	Reactive power L1 min	Var	✓	x	✓
6174/8174	7587	R	Reactive power L1 max	Var	✓	x	✓
6176/8176	7588	R	Reactive power L2 min	Var	✓	x	x
6178/8178	7589	R	Reactive power L2 max	Var	✓	x	x
6180/8180	7590	R	Reactive power L3 min	Var	✓	x	x
6182/8182	7591	R	Reactive power L3 max	Var	✓	x	x
6184/8184	7592	R	Apparent power L1 min	VA	✓	x	✓
6186/8186	7593	R	Apparent power L1 max	VA	✓	x	✓
6188/8188	7594	R	Apparent power L2 min	VA	✓	x	x
6190/8190	7595	R	Apparent power L2 max	VA	✓	x	x

6192/8192	7596	R	Apparent power L3 min	VA	✓	x	x
6194/8194	7597	R	Apparent power L3 max	VA	✓	x	x
6196/8196	7598	R	Power factor (PF) L1 min	-	✓	x	✓
6198/8198	7599	R	Power factor (PF) L1 max	-	✓	x	✓
6200/8200	7600	R	Power factor (PF) L2 min	-	✓	x	x
6202/8202	7601	R	Power factor (PF) L2 max	-	✓	x	x
6204/8204	7602	R	Power factor (PF) L3 min	-	✓	x	x
6206/8206	7603	R	Power factor (PF) L3 max	-	✓	x	x
6208/8208	7604	R	Ratio of reactive to active power L1 min	-	✓	x	✓
6210/8210	7605	R	Ratio of reactive to active power L1 max	-	✓	x	✓
6212/8212	7606	R	Ratio of reactive to active power L2 min	-	✓	x	x
6214/8214	7607	R	Ratio of reactive to active power L2 max	-	✓	x	x
6216/8216	7608	R	Ratio of reactive to active power L3 min	-	✓	x	x
6218/8218	7609	R	Ratio of reactive to active power L3 max	-	✓	x	x
6220/8220	7610	R	Phase-to-phase voltage L ₁₋₂ min	V	✓	✓	x
6222/8222	7611	R	Phase-to-phase voltage L ₁₋₂ max	V	✓	✓	x
6224/8224	7612	R	Phase-to-phase voltage L ₂₋₃ min	V	✓	✓	x
6226/8226	7613	R	Phase-to-phase voltage L ₂₋₃ max	V	✓	✓	x
6228/8228	7614	R	Phase-to-phase voltage L ₃₋₁ min	V	✓	✓	x
6230/8230	7615	R	Phase-to-phase voltage L ₃₋₁ max	V	✓	✓	x
6232/8232	7616	R	Average 3-phase voltage min	V	✓	x	x
6234/8234	7617	R	Average 3-phase voltage max	V	✓	x	x
6236/8236	7618	R	Average 3-phase current min	A	✓	✓	x
6238/8238	7619	R	Average 3-phase current max	A	✓	✓	x
6240/8240	7620	R	3-phase active power min	W	✓	✓	x
6242/8242	7621	R	3-phase active power max	W	✓	✓	x
6244/8244	7622	R	3-phase reactive power min	var	✓	✓	x
6246/8246	7623	R	3-phase reactive power max	var	✓	✓	x
6248/8248	7624	R	3-phase apparent power min	VA	✓	✓	x
6250/8250	7625	R	3-phase apparent power max	VA	✓	✓	x
6252/8252	7626	R	Power factor (PF) min	-	✓	✓	x
6254/8254	7627	R	Power factor (PF) max	-	✓	✓	x
6256/8256	7628	R	3-phase average min. ratio of reactive to active power	-	✓	✓	x
6258/8258	7629	R	3-phase average max. ratio of reactive to active power	-	✓	✓	x
6260/8260	7630	R	Frequency min	Hz	✓	✓	✓
6262/8262	7631	R	Frequency max	Hz	✓	✓	✓
6264/8264	7632	R	Average phase-to-phase voltage min	V	✓	✓	x
6266/8266	7633	R	Average phase-to-phase voltage max	V	✓	✓	x
6268/8268	7634	R	Averaged active power (P Demand) min	W	✓	✓	✓
6270/8270	7635	R	Averaged active power (P Demand) max	W	✓	✓	✓
6272/8272	7636	R	Averaged apparent power (S Demand) min	VA	✓	✓	✓
6274/8274	7637	R	Averaged apparent power (S Demand) max	VA	✓	✓	✓
6276/8276	7638	R	Averaged current (I Demand) min	A	✓	✓	✓
6278/8278	7639	R	Averaged current (I Demand) max	A	✓	✓	✓
6280/8280	7640	R	Current in neutral wire min	A	✓	x	x
6282/8282	7641	R	Current in neutral wire max	A	✓	x	x
6284/8284	7642	R	Reserved	-	-	-	-
6286/8286	7643	R	Reserved	-	-	-	-
6288/8288	7644	R	Reserved	-	-	-	-
6290/8290	7645	R	Reserved	-	-	-	-
6292/8292	7646	R	THD U1 min	%	✓	x	✓
6294/8294	7647	R	THD U1 max	%	✓	x	✓

6296/8296	7648	R	THD U2 min	%	✓	x	x
6298/8298	7649	R	THD U2 max	%	✓	x	x
6300/8300	7650	R	THD U3 min	%	✓	x	x
6302/8302	7651	R	THD U3 max	%	✓	x	x
6304/8304	7652	R	THD U min	%	✓	x	x
6306/8306	7653	R	THD U max	%	✓	x	x
6308/8308	7654	R	THD I1 min	%	✓	x	✓
6310/8310	7655	R	THD I1 max	%	✓	x	✓
6312/8312	7656	R	THD I2 min	%	✓	x	x
6314/8314	7657	R	THD I2 max	%	✓	x	x
6316/8316	7758	R	THD I3 min	%	✓	x	x
6318/8318	7759	R	THD I3 max	%	✓	x	x
6320/8320	7660	R	THD I min	%	✓	x	x
6322/8322	7661	R	THD I max	%	✓	x	x
6324/8324	7662	R	HarU1[2] 2nd harmonics of voltage of L1 phase	%	✓	x	✓
6326/8326	7663	R	HarU1[3] 3rd harmonics of voltage of L1 phase	%	✓	x	✓
:	:	R	:				
:	:	R	:				
6420/8420	7710	R	HarU1[50] 50th harmonics of voltage of L1 phase	%	✓	x	✓
6422/8422	7711	R	HarU1[51] 51st harmonics of voltage of L1 phase	%	✓	x	✓
6424/8424	7712	R	HarU2[2] 2nd harmonics of voltage of L2 phase	%	✓	x	x
6426/8426	7713	R	HarU2[3] 3rd harmonics of voltage of L2 phase	%	✓	x	x
:	:	R	:				
:	:	R	:				
6520/8520	7760	R	HarU2[50] 50th harmonics of voltage of L2 phase	%	✓	x	x
6522/8522	7761	R	HarU2[51] 51st harmonics of voltage of L2 phase	%	✓	x	x
6524/8524	7762	R	HarU3[2] 2nd harmonics of voltage of L3 phase	%	✓	x	x
6526/8526	7763	R	HarU3[3] 3rd harmonics of voltage of L3 phase	%	✓	x	x
:	:	R	:				
:	:	R	:				
6620/8620	7810	R	HarU3[50] 50th harmonics of voltage of L3 phase	%	✓	x	x
6622/8622	7811	R	HarU3[51] 51st harmonics of voltage of L3 phase	%	✓	x	x
6624/8624	7812	R	HarI1[2] 2nd harmonics of current of L1 phase	%	✓	x	✓
6626/8626	7813	R	HarI1[3] 3rd harmonics of current of L1 phase	%	✓	x	✓
:	:	R	:				
:	:	R	:				
6720/8720	7860	R	HarI1[50] 50th harmonics of current of L1 phase	%	✓	x	✓
6722/8722	7861	R	HarI1[51] 51st harmonics of current of L1 phase	%	✓	x	✓
6724/8724	7862	R	HarI2[2] 2nd harmonics of current of L2 phase	%	✓	x	x
6726/8726	7863	R	HarI2[3] 3rd harmonics of current of L2 phase	%	✓	x	x
:	:	R	:				
:	:	R	:				
6820/8820	7910	R	HarI2[50] 50th harmonics of current of L2 phase	%	✓	x	x
6822/8822	7911	R	HarI2[51] 51st harmonics of current of L2 phase	%	✓	x	x
6824/8824	7912	R	HarI3[2] 2nd harmonics of current of L3 phase	%	✓	x	x
6826/8826	7913	R	HarI3[3] 3rd harmonics of current of L3 phase	%	✓	x	x
:	:	R	:				
:	:	R	:				
6920/8920	7960	R	HarI3[50] 50th harmonics of current of L3 phase	%	✓	x	x
6922/8922	7961	R	HarI3[51] 51st harmonics of current of L3 phase	%	✓	x	x
6924/8924	7962	R	Average reactive power	var	✓	✓	✓
6926/8926	7963	R	Reactive power averaged min	var	✓	✓	✓
6928/8928	7964	R	Reactive power averaged max	var	✓	✓	✓
6930/8930	7965	R	Average active power factor (PF1+PF2+PF3)/3)	-	✓	x	✓
6932/8932	7966	R	Average active power factor min	-	✓	x	✓
6934/8934	7967	R	Average active power factor max	-	✓	x	✓

6938/8938	7969	R	Active imported 3-phase energy for the previous year (number of register 7563 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6940/8940	7970	R	Active imported 3-phase energy for the previous year (counter up to 9999.99 kWh)	kWh	✓	✓	✓
6942/8942	7971	R	Active exported 3-phase energy for the previous year (number of register 7565 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6944/8944	7972	R	Active exported 3-phase energy for the previous year (counter up to 99999.99 kWh)	kWh	✓	✓	✓
6946/8946	7973	R	Active imported 3-phase energy for the current year (number of register 7567 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6948/8948	7974	R	Active imported 3-phase energy for the current year (counter up to 99999,99 kWh)	kWh	✓	✓	✓
6950/8950	7975	R	Active exported 3-phase energy for the current year (number of register 7569 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6952/8952	7976	R	Active exported 3-phase energy for the current year (counter up to 99999.99 kWh)	kWh	✓	✓	✓
6954/8954	7977	R	Active imported 3-phase energy for the current month (number of register 7571 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6956/8956	7978	R	Active imported 3-phase energy for the current month (counter up to 99999,99 kWh)	kWh	✓	✓	✓
6958/8958	7979	R	Active exported 3-phase energy for the current month (number of register 7573 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6960/8960	7980	R	Active exported 3-phase energy for the current month (counter up to 99999.99 kWh)	kWh	✓	✓	✓
6962/8962	7981	R	Active imported 3-phase energy for the current week (number of register 7575 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6964/8964	7982	R	Active imported 3-phase energy for the current week (counter up to 99999.99 kWh)	kWh	✓	✓	✓
6966/8966	7983	R	Active exported 3-phase energy for the current week (number of register 7577 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6968/8968	7984	R	Active exported 3-phase energy for the current week (counter up to 99999.99 kWh)	kWh	✓	✓	✓
6970/8970	7985	R	Active imported 3-phase energy for the 48 hours (number of register 7579 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6972/8974	7986	R	Active imported 3-phase energy for the 48 hours (counter up to 99999.99 kWh)	kWh	✓	✓	✓
6974/8974	7987	R	Active exported 3-phase energy for the 48 hours (number of register 7581 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6976/8976	7988	R	Active exported 3-phase energy for the 48 hours (counter up to 99999.99 kWh)	kWh	✓	✓	✓
6978/8978	7989	R	Active imported 3-phase energy for the 24 hours (number of register 7583 overflows, reset after	100 MWh	✓	✓	✓

			9999.9 MWh is reached)				
6980/8980	7990	R	Active imported 3-phase energy for the 24 hours (counter up to 99999,99 kWh)	kWh	✓	✓	✓
6982/8982	7991	R	Active exported 3-phase energy for the 24 hours (number of register 7585 overflows, reset after 9999.9 MWh is reached)	100 MWh	✓	✓	✓
6938/8938	7969	R	Active exported 3-phase energy for the 24 hours (counter up to 99999.99 kWh)	kWh	✓	✓	✓

* In 3-phase 3-wire system (3Ph/3W) respectively THD U12, THD U23, THD U31,
THD U123

Table 22

Register address 16 bit 2x16 1032/ 2x16 3210	Operations	Description	Unit	3Ph / 4W	3Ph / 3W	1Ph / 2W
9000/9200	R	HarU1[52] 52nd harmonic of L1 phase voltage	%	✓	x	✓
9002/9202	R	HarU1[53] 53rd harmonic of L1 phase voltage	%	✓	x	✓
:	R	:				
:	R	:				
9020/9220	R	HarU1[62] 62nd harmonic of L1 phase voltage	%	✓	x	✓
9022/9222	R	HarU1[63] 63rd harmonic of L1 phase voltage	%	✓	x	✓
9024/9224	R	HarU2[52] 52nd harmonic of L2 phase voltage	%	✓	x	x
9026/9226	R	HarU2[53] 53rd harmonic of L2 phase voltage	%	✓	x	x
:	R	:				
:	R	:				
9044/9244	R	HarU2[62] 62nd harmonic of L2 phase voltage	%	✓	x	x
9046/9246	R	HarU2[63] 63rd harmonic of L2 phase voltage	%	✓	x	x
9048/9248	R	HarU3[52] 52nd harmonic of L3 phase voltage	%	✓	x	x
9050/9250	R	HarU3[53] 53rd harmonic of L3 phase voltage	%	✓	x	x
:	R	:				
:	R	:				
9068/9268	R	HarU3[62] 62nd harmonic of L3 phase voltage	%	✓	x	x
9070/9270	R	HarU3[63] 63rd harmonic of L3 phase voltage	%	✓	x	x
9072/9272	R	HarI1[52] 52nd harmonic of L1 current voltage	%	✓	x	✓
9074/9274	R	HarI1[53] 53rd harmonic of L1 current voltage	%	✓	x	✓
:	R	:				
:	R	:				
9092/9292	R	HarI1[62] 62nd harmonic of L1 current voltage	%	✓	x	✓

9094/9294	R	Harl1[63] 63rd harmonic of L1 current voltage	%	✓	x	✓
9096/9296	R	Harl2[52] 52nd harmonica of L2 current voltage	%	✓	x	x
9098/9298	R	Harl2[53] 53rd harmonic of L2 current voltage	%	✓	x	x
:	R	:				
:	R	:				
9116/9316	R	Harl2[62] 62nd harmonic of L2 current voltage	%	✓	x	x
9118/9318	R	Harl2[63] 63rd harmonic of L2 current voltage	%	✓	x	x
9120/9320	R	Harl3[52] 52nd harmonica of L3 current voltage	%	✓	x	x
9122/9322	R	Harl3[53] 53rd harmonic of L3 current voltage	%	✓	x	x
:	R	:				
:	R	:				
9140/9340	R	Harl3[62] 62nd harmonic of L3 current voltage	%	✓	x	x
9142/9342	R	Harl3[63] 63rd harmonic of L3 current voltage	%	✓	x	x

13 FIRMWARE UPGRADE

13.1 Update of the meter website

The website can be updated via the FTP server.

We update the website of the meter in the *Website update* tab. Copy the file NR30_upd.tar to the main folder of the meter. Then turn the meter off and on, i.e. reset the meter. The NR30_upd.tar file will be unpacked to the correct folders. It can take about 1 minute. The meter screen will display messages informing about the progress of the unpacking process.




Fig.31. Window view - website update file


13.2 Firmware upgrade

Before updating the meter's firmware, check the loader version installed in the meter. In the **Information** mode, read the loader version.

13.2.1 Firmware upgrade – for loader version v1.0x (x=1..9)

NR30 meters have a feature that allows the user to upgrade the software using a PC with eCon software. Free eCon software and update files are available at www.lumel.com.pl. Upgrade of the meter software (firmware) can be done via the USB (baud rate: 115200 bps, mode: 8N2, address: 1) interface. The update is done in LUMEL UPDATER tab.

a)



b)




Fig.32. View of program window: a) eCon, b) firmware upgrade

Caution! After upgrading the software, the user should set the factory settings of the meter, thus it is recommended to preserve the initial meter parameters before the upgrade with the use of eCon software.

After starting eCon the serial port, speed, mode and meter address should be set in the settings. Then select NR30 meter and click **Configure** To read all the settings, click the down arrow, then the floppy icon to save the settings to a file (to restore them later). After selecting **Update firmware** (in the upper right corner of the screen) *Lumel Updater* (LU) window will open - Fig. 3 2.b. Press **Connect**. **Messages** information window contains info about the progress of the upgrade process. When the port is properly opened the display shows: *Port opened*. There are two ways to enter the upgrade mode: remotely through the LU (based on settings in eCon - address, mode, speed, COM port) and by turning on the meter power with the button pushed (when entering the bootloader mode with the button, communication parameters: speed 9600, RTU8N2, address 1). The display will show boot with bootloader version, and LU program will show the message *Device found* and the name and program version of the connected device. Press the „....” button and select the meter update file. When the file is properly opened *File opened* message is displayed. Press the **Send** button. After successful upgrade the meter switches to normal operation, and the information window shows *Done* and the upgrade duration. After closing the LU window, go to **Service Parameters**, select **Set Meter Defaults** and press the **Restore** button. Then press the folder icon to open the previously saved settings file and press the up arrow to save the settings in the meter. The current software version can also be checked by reading the greeting messages of the meter after powering up.

Caution! Turning off the power during the software upgrade may result in permanent damage to the meter!

13.2.2 Firmware upgrade – for loader version 2.xx (x=00..99)

Firmware upgrade can be done via FTP server.

Copy the *update.bin* file to the root folder of the meter. Then turn the meter off and on, i.e. *Restart* the meter. The message *Update...* will appear on the meter screen, informing about the ongoing software update.




Fig.33. View of the FileZilla program window - during the software update.

14 ERROR CODES

During operation of the meter, error messages may appear on the display. The causes of the errors are listed below.

Error:

MEM_FR, CAL_IN, SDCARD – displayed when the memory of the meter is corrupted. The meter must be sent to the manufacturer.

P.CFG – displayed when the operating parameters of the meter are incorrect. The factory settings must be restored (from the menu "Settings -> Set all defaults" or via RS485).

P.PAGE – displayed when the parameters related to the configuration of displayed parameters in the meter are incorrect. The factory settings should be restored (from the menu "Displaying -> Settings -> Set page defaults "or via RS485).

P.READ – displayed when the parameters related to registers from the modbus 42xx group of addresses are incorrect. The factory settings must be restored (from the menu " Modbus -> Set defaults 42xx" or via RS485).

ENERGY – displayed when an error occurs in the value in one of the energy counters of the meter. The factory settings must be restored (from the menu " Parameters -> Del energy counters" or via RS485).

- ^^^^ – upper exceeding. The value is measured outside the measurement range.
- vvvv – lower exceeding. The value is measured outside the measurement range.

15 TECHNICAL DATA

Measurement ranges and acceptable errors

Table 23

Measured quantity	Measuring range	L1	L2	L3	Σ	Class
Current I: 1/5 A 1 A~ 5 A~ 63 A~	0,002 .. 0,100 .. 1,200 A 0,010 .. 0,500 .. 6,000 A 0,10 .. 6,3 .. 70,00 A ...100,00 kA (tr_I#1)	•	•	•		0.2 (EN 61557-12)
Voltage U L-N: 57,7 V~ 100 V~ 230 V~ 400 V~	5.700 .. 11.500 .. 70.000 V 11.000 .. 20.000 .. 120.00 V 23.000 .. 46.000 .. 276.00 V 40.000 .. 80.000 .. 480.00 V ...1920.0 kV	•	•	•		0.2 (EN 61557-12)
Voltage U L-L: 100 V~ 170 V~ 400 V~ 690 V~	10.000 .. 20.000 .. 120.00 V 17.000 .. 34.000 .. 204.00 V 40.000 .. 80.00 .. 480.00 V 69.000 .. 138.00 .. 830.00 V ...1999.0 kV (tr_U#1)	•	•	•		0.5 (EN 61557-12)
Active power P	-19999 MW .. 0.000 W19999 MW (tr_U#1,tr_I#1)	•	•	•	•	0.5 (EN 61557-12)
Reactive power Q	-19999 MVar .. 0.000 Var19999 MVar (tr_U#1,tr_I#1)	•	•	•	•	1 (EN 61557-12)
Apparent power S	0.000 .. 1999.9 VA19999 MVA (tr_U#1,tr_I#1)	•	•	•	•	0.5 (EN 61557-12)
Active energy EnP / imported or exported /	0.0 .. 99 999 999. 9 kWh				•	0.2S (EN 62053-22)
Reactive energy EnQ /Inductive or capacitive/	0.0 .. 99 9 999, 999 kVarh				•	1 (EN 61557-12)
Apparent energy EnS	0.0 .. 99 999 999. 9 kVAh				•	0.5 (EN 61557-12)
Power factor active PF	-1.00 .. 0 .. 1.00	•	•	•	•	1 (EN 61557-12)
tg factor	-999,99 .. 0 .. 999,99	•	•	•	•	1
Frequency f	45.000 .. 65.000 Hz				•	0.1 (EN 61557-12)
Total harmonic distortion of voltage THDU, and current THDI	0.0 .. 100.0 %	•	•	•	•	5 (EN 61557-12)
Amplitudes of voltage harmonics $U_{h2} \dots U_{h63}$, and current $I_{h2} \dots I_{h63}$	0.0 .. 100.0 %	•	•	•		II (IEC61000-4-7)

tr_I - Ratio of current transformer = Primary current of transformer / Secondary current of current transformer,

tr_U - Ratio of voltage transformer = Primary voltage of transformer / Secondary voltage of voltage transformer,

¹⁾ Clasc 0,5 S acc. to PN-EN 62053-22

Power consumption:

- in power supply circuit ≤ 6 VA
- in voltage circuit ≤ 0.5 VA
- in current circuit ≤ 0.1 VA (1/5 A); ≤ 2.0 VA (63 A)

Readout field

LCD display 20 x 4 rows; white background, black characters

Relay outputs (A1, A2)

2 programmable relays, volt free NO contacts, resistive load 0.5 A/250 V a.c. or 5 A/30 V d.c.

Number of switchings: mechanical minimum 5×10^6
electric minimum 1×10^5

RS485 serial interface

Modbus RTU 8N2,8E1,8O1,8N1. Address 1..247,

Baud rate 4.8, 9.6, 19.2, 38.4, 57.6, 115.2 kbit/s

	maximum time to commence the response: 600 ms
Ethernet Interface	10/100 Base-T, RJ45 socket, Web Server, FTP server. Modbus TCP/IP server, DHCP client
Sampling	A/C converter 16-bit Sampling rate 6.4 kHz for 50 Hz 7.68 kHz for 60 Hz Simultaneous sampling across all channels, 128 samples per period
Harmonics	Harmonics series (n) 1..63 The harmonic distortion factor referred to the fundamental component of THD voltage, THD current waveform (n=2..63) 0,0 ..100.0 % FFT analysis (Fast Fourier Transform),
Real-time clock	±20 ppm, battery of real time clock CR1220
Recording	Archiving period (recording interval) 1..3600 sec. Recording start modes: n_on, noFF, on,oFF, H_on, HoFF, 3non, 3noF, 3_on, 3_oF, Recording time: depends on the recording interval, e.g. for 1 second interval it is about 220 days. 8GB file archive memory
Terminals	direct connection (63A) indirect connection (1/5A)
Cross-section	
wire	2.5 .. 16 mm ²
cable	4 .. 16 mm ²
Clamping screws	M5
Tightening torque	1.2 .. 2.0 Nm
	1.0 Nm
Degree of protection provided by housing	
from the front side	IP 50
terminals	IP 00
Weight	0.3 kg
Dimensions	105 x 110 x 60 mm
Reference conditions and rated operating conditions.	
- power supply	85..253 V a.c. (40..50..400) Hz or 90..300 V d.c. or 20..40 V a.c. or 20..60 V d.c.
- input signal:	0 .. <u>0.1..1.2I_n</u> for versions 1/5A; 0 .. <u>0,...1.1I_n</u> for versions 63A; <u>0.1..0.2..1.2U_n</u> for current, voltage, PF _i , tg _i frequency 45 .. <u>50 .. 60 .. 65</u> Hz; sinusoidal (THD ≤ 8%)
- power factor	<u>-1...0....1</u>
- ambient temperature	-10.. <u>23..+55</u> °C, class K55 acc. to EN61557-12
- storage temperature	-20.. <u>+70</u> °C
- humidity	0 .. <u>40 .. 60 .. 95</u> % (no condensation)

- acceptable crest factor :
- current 2
- voltage 2
- external magnetic field $\leq 40 \dots 400 \text{ A/m d.c.}$
 $\leq 3 \text{ A/m a.c. } 50/60 \text{ Hz}$
- short-term overload
- voltage inputs 5 sec. 2 Un
- current inputs 1 sek. 50 A (for versions In 1 A/ 5 A)
1 sec. 630 A (for versions In 63 A)
- operation position any
- warm-up time 15 min.

Real-time clock battery: CR1220

Additional errors:

in % of intrinsic error

- due to ambient temperature changes $< 50 \% / 10 \text{ }^{\circ}\text{C}$
- for THD > 8% $< 50 \%$

Standards met by the meter

Electromagnetic compatibility

- immunity in industrial environments EN 61000-6-2

resistance to induced common voltages of radio frequency:

- level 2 in the frequency range of 0.15 .. 1 MHz,
- level 3 in the frequency range of 1 MHz .. 80 MHz,
 - noise emission acc. to EN 61000-6-4

Safety requirements:

according to EN 61010-1 standard

- insulation between circuits: basic,
- installation category III for voltages up to 300V in relation to earth
- installation category II for voltages up to 600V in relation to earth
- degree of pollution 2
- maximum operating voltage relative to earth
 - for power circuits and relay outputs 300 V
 - for measurement input 500 V
 - for RS485, Ethernet circuits, analog outputs: 50 V
- altitude < 2000m


16 ORDERING CODES

Ordering code of NR30 meter of power network parameters.

Table 24

Code	Description
NR30IoT 2221MSM0*	Rail-mounted 3-phase power network meter (MQTT) NR30IoT Current input 63A, Voltage input 3x230/400V or 3x400/690V, 2x relays, Ethernet and RS-485 interface, internal memory 8GB, supply 85-253V a.c. Or 90-300V d.c., MQTT protocol, Supervisory relay, documentation and descriptions in Polish and English version, test certificate
NR30IoT 1221MSM0*	Rail-mounted 3-phase power network meter (MQTT) NR30IoT Current input 1A/5A, X/1A, X/5A, Voltage input 3x230/400V or 3x400/690V, 2x relays, Ethernet and RS-485 interface, internal memory 8GB, supply 85-253V a.c. or 90-300V d.c., MQTT protocol, Supervisory relay, documentation and descriptions in Polish and English version, test certificate
NR30IoT 1222MSM0*	Rail-mounted 3-phase power network meter (MQTT) NR30IoT Current input 1A/5A, X/1A, X/5A, Voltage input 3x230/400V or 3x400/690V, 2x relays, Ethernet and RS-485 interface, internal memory 8GB, supply 20-40V a.c. or 20-60V d.c., MQTT protocol, Supervisory relay, documentation and descriptions in Polish and English version, test certificate

* Upon agreement, an option to order a calibration certificate for the product is available against payment. Then, in the execution code, in the place of the last character, enter the digit **2**, e.g. **NR30IoT 1222MSM2**. The customer will then receive a standard test certificate and a calibration certificate (against payment).



LUMEL

LUMEL S.A.

ul. Ślubicka 4, 65-127 Zielona Góra, Poland
tel.: +48 68 45 75 100, fax +48 68 45 75 508
www.lumel.com.pl

Technical support:

tel.: (+48 68) 45 75 143, 45 75 141, 45 75 144, 45 75 140
e-mail: export@lumel.com.pl

Export department:

tel.: (+48 68) 45 75 130, 45 75 131, 45 75 132
e-mail: export@lumel.com.pl

Calibration & Attestation:

e-mail: laboratorium@lumel.com.pl